arXiv:2212.13655v1 [eess.SY] 28 Dec 2022

Electric-Gas Infrastructure Planning for Deep Decarbonization of Energy Systems

Rahman Khorramfar*, Dharik Mallapragada, Saurabh Amin

Abstract

The transition to a deeply decarbonized energy system requires coordinated planning of infrastructure investments and operations serving multiple end-uses while considering technology and policy-enabled interactions across sectors. Electricity and natural gas (NG), which are vital vectors of today's energy system, are likely to be coupled in different ways in the future, resulting from increasing electrification, adoption of variable renewable energy (VRE) generation in the power sector and policy factors such as cross-sectoral emissions trading. This paper develops a least-cost investment and operations model for joint planning of electricity and NG infrastructures that considers a wide range of available and emerging technology options across the two vectors, including carbon capture and storage (CCS) equipped power generation, low-carbon drop-in fuels (LCDF) as well as long-duration energy storage (LDES). The model incorporates the main operational constraints of both systems and allows each system to operate under different temporal resolutions consistent with their typical scheduling timescales. We apply the modeling framework to evaluate power-NG system outcomes for the U.S. New England region under different technology, decarbonization goals, and demand scenarios. Under a global emissions constraint, ranging between 80-95% emissions reduction compared to 1990 levels, the least-cost solution disproportionately relies on using the available emissions budget to serve non-power NG demand and results in the power sector using only 15-43% of the emissions budget. Increasing electrification of heating in the buildings sector results in greater reliance on wind and NG-fired plants with CCS and results in similar or slightly lower total system costs as compared to the business-as-usual demand scenario with lower electrification of end-uses. Interestingly, although electrification reduces non-power NG demand, it leads to up to 20% increase in overall NG consumption (both power and non-power), resulting from the increased role for CCS in the power sector, and a similar increase in power system investment costs. The availability of low-cost LDES systems reduces the extent of coupling of electricity and NG systems by reducing overall NG consumption by up to 95% compared to scenarios without LDES, while also reducing total systems costs by up to 4.5% for the evaluated set of scenarios.

*Corresponding author.

Rahman Khorramfar is affiliated with MIT Energy Initiative (MITEI) and Laboratory for Information & Decision Systems (LIDS); Dharik Mallapragada is affiliated with MITEI; Saurabh Amin is affiliated with Civil and Environmental Engineering (CEE), MITE, and LIDS, Massachusetts Institute of Technology, Cambridge, MA, USA. {khorram, dharik, amins}@mit.edu.

Authors acknowledge support from MIT Energy Initiative Future Energy System Center, MIT Climate Grand Challenge "Preparing for a new world of weather and climate extremes", and MIT Energy Initiative Project Hurricane Resilient Smart Grids.

1 Introduction

Electricity power and NG are important vectors for energy systems in the U.S. and other regions, with the infrastructure for their supply becoming increasingly coupled over the past two decades. For instance, electricity and NG represented 32% of final energy demand in the U.S as of 2021 as compared to 22% in 2005 [25]. Over the same period, the share of NG-based power generation in the electricity generation mix doubled to 38% of supply in 2021. This shift away from coal to NG and gradually increasing share of variable renewable energy (VRE) has resulted in the U.S. CO_2 emissions being 32% lower in 2021 compared to 2005 levels [26]. In many U.S. regions with rapidly growing VRE generation, like California and Texas, the flexibility of NG power plants, both within a day and across days, is often used for managing VRE supply and demand variations and ensuring reliable grid operations [38]. The importance of NG for reliable power systems operations was exemplified by the Texas freeze of February 2021 where outages in the NG system were identified as the primary cause of electricity blackouts [14]. Beyond operations, the planning of electricity and NG infrastructure is becoming more coupled owing to the growing policy interest in electrification for achieving economy-wide decarbonization by mid-century. In this article, we develop a model for joint planning of electricity and NG infrastructure that considers spatial, temporal and technologically resolved representation of the system operations. We use the model to explore the pathways for deep decarbonization of these systems and the other end-use sectors where these vectors are used (e.g. buildings) under plausible technology, demand and policy scenarios.

Policies aimed at economy-wide CO_2 emissions reduction further increase the interdependency between electricity and NG infrastructure planning, beyond levels seen currently. First, electrification of end-uses, such as heating, in the building sector reduces NG consumption in favor of increasing electricity consumption, which can increase peak electricity demand and its timing (e.g. summer to winter peaking shifts [34, 47].) Second, increasing the share of VRE generation in the power sector coupled with the adoption of flexible short-duration and long-duration energy storage resources is likely to alter the cost-optimal operational schedule of NG power plants, and hence impact the pattern of NG withdrawals from the gas infrastructure for power generation. Ultimately, these patterns affect the cost-effectiveness of the available NG-based power generation technologies and the incentive to invest in new NG pipelines. For example, reduced capacity utilization of NG-power generation is expected to promote more investments in higher operating cost, lower capital cost combustion turbines in comparison to lower operating cost, higher capital cost combined cycle gas turbine (CCGT) plants [18, 36]. Third, the scope and stringency of emissions reduction policies can shape the investments in NG and electricity infrastructure in several ways. For example, policies aimed at *combined* emission reductions without specific sectoral emissions reduction requirements may facilitate emissions trading across sectors to minimize the system cost of decarbonization. Similarly, the policy stringency will impact the relative role for low-carbon supply options like CCGT equipped with carbon capture and storage (CCS) for power generation, long-duration energy storage (LDES) as well as the use of synthetic or renewable-sourced low-carbon drop-in fuels (LCDFs), whose availability and cost is highly uncertain [36, 41]. Understanding the interplay between these options requires models for coordinated planning of electricity and NG infrastructure that consider investments and operations of generation, transmission,

storage and end-use for each vector, which is the focus of our article.

Traditionally, generation and transmission expansion for electricity systems have been treated as separate problems in the literature [39]. However, in recent years, there has been a growing interest in integrated generation transmission expansion planning (GTEP)[70, 20, 8, 67, 42]. These studies are motivated by the growing importance of VRE generation in power systems and the spatially variable nature of these resources that makes transmission expansion more important [13, 11]. Still, the majority of GTEP models primarily focus on power systems without accounting for the operational interdependencies with the NG system. A tri-level model with demand uncertainty is proposed in [54] in which the upper level is the transmission expansion problem, the intermediate level is the generation expansion problem, and the lower level deals with market operation decisions. Aghaei et al. [2] develop a probabilistic model incorporating reliability measures in the objective function. Guerra et al. [31] propose a model with demand side control, power reserve, and emission constraints. Uncertainty in peak demand and generation output is considered in [5] and a stochastic adaptive robust optimization model is proposed. Jayadev et al. [36] develop a cost-optimal, multi-stage planning model for the US power system and show that substantial decarbonization is moderately costly and is accompanied with investments in new NG generation capacity that has declining utilization rates. Li et al. [42] compare three mixed-integer formulations and develop two Benders algorithms where the first algorithm decomposes the problem based on the planning years, whereas the second one is based on operational decisions. The literature of expansion models in energy systems is rich and a thorough treatment of the subject can be found in recent review papers such as Dagoumas et al. [19] and Farrokhifar et al. [29].

For the reasons described above, there is a growing interest in expanding the scope of GTEP to consider investments in both power and NG infrastructure. Unsihuay et al. [65] propose a multistage linear model for Brazilian integrated power-NG systems. Qiu et al. [55] consider AC power flow and propose linearization methods for the resulting nonlinear program. Shao et al. [61] consider a joint power and NG transportation system and propose an algorithm to enhance power grid resiliency under extreme conditions. A two-stage and multistage stochastic programming approaches are proposed in [72] and [20], respectively. Zhang et al.[71] propose a security-constrained model that considers $N-1$ contingency in both power and NG system. More recently, Von Wald et al. [67] develop a multi-period generation expansion model with detailed operational constraints. They consider endogenous electrification of end-use appliance under system-specific emission constraints as well as the role for hydrogen blending and its application in an abstract case study. Although the existing literature addresses many important aspects of capacity expansion in power-NG networks, a natural question is how the interdependent nature of these systems is impacted by changes in demand for electricity and NG, in particular due to building sector electrification. Moreover, there is no thorough treatment of the role of emerging technologies such as CCS-equipped power generation, LCDFs and LDES in a unified modeling framework.

We address these gaps by developing a novel GTEP model for planning power-NG systems under deep decarbonization scenarios (i.e., stringent emissions reduction goals). Importantly, our model captures the impact of emerging solutions on the energy supply-side highlighted above as well as demand-side interventions in the form of increased electrification of the building sector. The model fidelity includes representation of both NG and electricity networks as well as hourly and daily supply-demand balanc-

ing of the electricity and NG system operations, respectively. The modeling framework also includes CO_2 capture and storage infrastructure investment for CCGT-CCS plants.

We apply our model to a case study of the U.S. New England region where we explore system outcomes for alternative technology, sectoral coordination, demand and deep decarbonization scenarios. [1] Our results reveal that electrification of the building sector in conjunction with other emerging supply-side mitigation options provides a cost-effective means for steep emission reductions (80-95% compared to 1990 levels) across both systems and end-use sectors relying on these vectors. Among supply-side options, a common strategy is the substantial investment in VRE and Li-ion storage capacity that collectively represent 15-19% of total system costs and 42-43% of total power system cost across all the emissions, demand and technology scenarios evaluated here. Across the scenarios, we find that the cost-optimal solution involves a reliance on a portfolio approach for system balancing to meet demands for both vectors under emissions constraints, which includes the use of CCS, LCDF and LDES along with Li-ion storage and VRE generation. The availability of LCDF favors greater use of existing generation capacity, namely NG and nuclear, while reducing the need to deploy CCGT-CCS and additional VRE capacity. For levels of end-use electrification considered here, LCDF is also deemed necessary to ensure that all the imposed demand can be served without violating emissions constraints.

The availability of LDES contributes to modest system reductions while shifting the power system generation portfolio to favor wind generation (both onshore and offshore) and reducing the need to invest in CCGT-CCS and short-duration storage. This shift toward wind vs. solar PV generation is more pronounced in the scenario with increased electrification of the building sector owing to increased demand in winter months when solar resource quality in the New England region is relatively low. A counter-intuitive finding is that High electrification, which reduces non-power NG demand, leads to upto 20% greater overall NG consumption (both power and non-power) than the business-as-usual scenarios with lower electrification, with the additional NG being used in the power sector in conjunction with CCS. Overall, the findings highlight that although there is an obvious need to deploy substantial quantities of VRE and Li-ion storage to support power system decarbonization, the uncertainty in supply-side and demand-side drivers across infrastructures for electricity and NG leaves open the possibility of multiple pathways for deep decarbonization of systems.

The rest of the paper is organized as follows. Section 2 formulates the joint power-NG system planning model. The details of the case study on the New England region are explained in Section 3. Results and analysis with key takeaways are discussed in Section 4. The concluding remarks and areas of future work are discussed in Section 5.

2 Model Formulation

Our model, referred as JPoNG, determines the minimum cost planning decisions for power and NG systems considering the two systems' interdependency. The proposed model considers a range of generation and storage technologies whose operations are

[1] our model relies on renewable resource profiles, load projections, technology cost assumptions and approximate gas and electric network topology based on publicly available data (see the Appendix) for the region. Thus the model is representative but not field-validated, hence our results should be interpreted in the context of technology adoption trends and requirements, and not as exact projections for the region.

modeled via operational and policy constraints across a set of representative periods. The formulation allows different temporal resolutions for the operation of both systems since the data availability or planning requirements can be different for each system. For example, decisions related to power generation, such as dispatch amounts and unit commitment, require hourly resolution. However, NG system operation does not involve generation decisions and only deals with transmission and storage operations for which daily resolution may be sufficient. Moreover, because of the ability for NG pipelines to also provide some storage via line packing, daily resolution for scheduling NG operation could facilitate management of intra-day variations in NG demand. In the model, the operations of both systems are coupled through two sets of constraints. The first set ensure NG flow to the power system. The second coupling constraint limits the CO_2 emission incurred by consuming fossil-derived NG in both power and NG systems. This is in contrast with previous studies where the emission limit is either applied to power system only [42], or are imposed separately for each system [67].

As a common practice in the literate to enhance the scalibility of the GTEP [67, 42, 62], the scheduling of power system operations is modeled over a set of representative days. Long-term planning of NG system is usually planned on yearly [55, 4, 59], monthly [32], or daily [15, 67] basis. Some studies use different resolution for power and NG systems. Power and gas systems operate on hourly basis and daily basis over representative time periods in Von Wald et al. [67]. Saedi et al. [58] used half-hour resolution for the power system and daily resolution for the NG. The authors propose a two-phase model in which the the power system operations are planned in the first phase and the second phase determines the optimal gas flow. We take a similar approach here and consider hourly and daily time resolution for the power and NG systems, respectively. However, we only consider representative days for the power system and model the operations of the NG system across all days of the year. Although the sub-daily representation can be more advantageous to capture fine-grained operational features, the daily planning in the context of capacity expansion has several merits. First, it enhances the scalibility of the model by significantly reducing the number of decision variables and constraints, which allows for introducing complexity in other dimensions of the problem, such as using integer variables for investments decisions, as is done here . Second, it no longer necessitates using nonlinear steady-state gas flow that relates nodal pressure to flow. In other words, a non-compressible formulation can be employed for gas flow in case of daily resolution in which the gas is treated like liquid [45]. The third advantage stems from the data availability. In many cases, data to characterize the NG network operations for real-world systems, such as our case study, is not publicly available at the resolution needed for hourly operations considering pressure variations. Fig. 1 illustrates our modeling approach for the time resolutions of the both systems.

The network representation in the model consists of three sets of nodes as depicted in Figure 2. The first set represents power system nodes and is characterized by different generation technologies (i.e., plant types), demand, storage, and the set of adjacent nodes by which the node can exchange electricity. The second set of nodes are NG nodes each of which are associated with injection amount, demand, and its adjacent nodes. Storage tanks, vaporization and liquefaction facilities, which are commonly used in the non-reservoir storage of NG, collectively form the third set of node referred as storage-vaporization-liquefaction (SVL) nodes. We allow for the possibility of NG storage infrastructure to be located far from demand or injection points in the network,




Figure 1: Illustration of the model's temporal resolution for the case of two representative days used for power systems operations. The top row represents planning days in a year, with days 3 and 7 as representative days forming the set $\mathfrak{R}$. The bottom row show the hours corresponding to representative days. The set of planning periods for the NG system ($\mathcal{T}^{\mathrm{g}}$) is the entire year. The set of planning periods for the power system ($\mathcal{T}^{\mathrm{e}}$) is the chronologically ordered set of hours in the representative days whose mapping to their original index is given by $\phi^{\mathrm{e}}_t, t \in \mathcal{T}^{\mathrm{e}}$. The set of hours in their original indexing is denoted by $\mathfrak{T}^{\mathrm{e}}_\tau$ with t^{start}_τ and t^{end}_τ signifying the starting and ending hours for the representative day τ.

as per existing practice [3] (see C.3 for detailed discussion). Accordingly, our model makes a distinction between NG and SVL nodes to account for their distinct locations. We also allow the NG system to use LCDF which represents a renewable source of fuel that is interchangeable with NG and hence can be imported and transported by the NG pipelines [18]. We present power and NG systems' model as well as coupling constraints separately for the ease of exposition. The full description of the mathematical notation used in the formulation is described in A.




Figure 2: Flow variables between different nodes. In our model, power nodes can be connected by multiple bi-directional transmission lines denoted by $f^{\mathrm{e}}_{\ell t}$. Each power node operates a set of local gas-fired plants by drawing gas from nodes that are connected to it. The variable $f^{\mathrm{ge}}_{kn\tau}$ captures this flow. Each NG node is connected to its adjacent SVL nodes through two unidirectional pipelines where one is from NG to SVL's liquefaction facilities denoted by $f^{\mathrm{gl}}_{kj\tau}$; and the other one from SVL's vaporization facility to NG node denoted by $f^{\mathrm{vg}}_{jk\tau}$. The variable $f^{\mathrm{g}}_{\ell\tau}$ denotes the pipe flow between NG nodes. NG nodes can be connected by one or more uni-directional pipelines, but only one connection is depicted here. Candidate transmission lines and pipelines are not shown in this figure.

2.1 Power System Model

Objective Function:

$$\min \sum_{n\in\mathcal{N}^{\mathrm{e}}}\sum_{i\in\mathcal{P}}(C_i^{\mathrm{inv}}x_{ni}^{\mathrm{est}} + C_i^{\mathrm{fix}}x_{ni}^{\mathrm{op}} + \sum_{r\in\mathcal{S}_n^{\mathrm{e}}}(C_r^{\mathrm{pInv}} + C^{\mathrm{pFix}})y_{nr}^{\mathrm{eCD}})$$

$$+ \sum_{n\in\mathcal{N}^{\mathrm{e}}}\sum_{r\in\mathcal{S}_n^{\mathrm{e}}}(C_r^{\mathrm{EnInv}} + C^{\mathrm{EnFix}})y_{nr}^{\mathrm{eLev}} \tag{1a}$$

$$+ \sum_{n\mathcal{N}^{\mathrm{e}}}\sum_{i\in\mathcal{P}} C_i^{\mathrm{dec}}x_{ni}^{\mathrm{dec}} \tag{1b}$$

$$+ \sum_{n\in\mathcal{N}^{\mathrm{e}}}\sum_{i\in\mathcal{P}}\sum_{t\in\mathcal{T}^{\mathrm{e}}} w_t p_{nti} C_i^{\mathrm{var}} \tag{1c}$$

$$+ \sum_{n\in\mathcal{N}^{\mathrm{e}}}\sum_{t\in\mathcal{T}^{\mathrm{e}}}\sum_{i\in\mathcal{P}} w_t C_i^{\mathrm{startUp}}x_{nti}^{\mathrm{up}} \tag{1d}$$

$$+ \sum_{l\in\mathcal{L}^{\mathrm{e}}} C_\ell^{\mathrm{trans}}z_\ell^{\mathrm{e}} \tag{1e}$$

$$+ \sum_{n\in\mathcal{N}^{\mathrm{e}}} d_n C_{\mathrm{CO_2}}^{\mathrm{inv}}\kappa_n^{\mathrm{pipe}} + C_{\mathrm{CO_2}}^{\mathrm{str}}\sum_{n\in\mathcal{N}^{\mathrm{e}}}\sum_{t\in\mathcal{T}^{\mathrm{e}}} w_t\kappa_{nt}^{\mathrm{capt}} \tag{1f}$$

$$+ \sum_{n\in\mathcal{N}^{\mathrm{e}}}\sum_{i\in\mathcal{P}}\sum_{t\in\mathcal{T}^{\mathrm{e}}} w_t p_{nti}(C_i^{\mathrm{fuel}}h_i) \tag{1g}$$

$$+ \sum_{n\in\mathcal{N}^{\mathrm{e}}}\sum_{t\in\mathcal{T}^{\mathrm{e}}} w_t C_n^{\mathrm{eShed}}a_{nt}^{\mathrm{e}} \tag{1h}$$

The objective function (1) minimizes the total investment and operating costs incurred in the power system. The first term (1a) is the investment and fixed operation and maintenance (FOM) costs for generation and storage. The term (1b) captures the cost of plant retirement or decommissioning. The variable operating and maintenance (VOM) cost is represented by the term (1c). The fourth term (1d) corresponds to startup costs of power plants with unit commitment constraints (i.e. thermal power plants). The network expansion costs is included in the term (1e). The cost of CO_2 transport and storage infrastructure required to accompany CCGT-CCS power generation is incorporated by term (1f) which also captures the cost associated with establishing CO_2 pipelines and storage. Here, we conservatively assume that each CO_2 pipeline connects a power node to the storage site, which ignores the possibility of meshed network design for CO_2 transport. The cost of fuel consumption for non NG-fired power plants (i.e., nuclear) is ensured by term (1g). The term (1h) penalizes the load shedding in the power system.

Investment and Unit Commitment: For every $n \in \mathcal{N}^{\mathrm{e}}, i \in \mathcal{P}$

$$x_{ni}^{\mathrm{op}} = I_{ni}^{\mathrm{num}} - x_{ni}^{\mathrm{dec}} + x_{ni}^{\mathrm{est}} \tag{2a}$$

$$x_{nti} - x_{n,t-1,i} = x_{nti}^{\mathrm{up}} - x_{nti}^{\mathrm{down}} \qquad t \in \mathcal{T}^{\mathrm{e}} \tag{2b}$$

$$x_{nti} \le x_{ni}^{\mathrm{op}} \qquad t \in \mathcal{T}^{\mathrm{e}} \tag{2c}$$

Constraints (2a) model the number of operating plants. The unit commitment constraints for each node and plant type are presented in (2b) which computes the number of plants committed, started up, or shut down across the hours of the representative days. Constraints (2c) limit the number of committed units to the number of available ones. As per other similar studies [53, 60, 42, 67], we relaxed the integrality of unit commitment decisions which has been shown to introduce relatively small numerical error while significantly reducing the computational complexity of the problem.

Generation, Ramping, and Load Shedding: For every $n \in \mathcal{N}^{\mathrm{e}}, t \in \mathcal{T}^{\mathrm{e}}$

$$L_i^{\mathrm{prod}} x_{nti} \leq p_{nti} \leq U_i^{\mathrm{prod}} x_{nti} \qquad i \in \mathcal{H} \tag{3a}$$

$$|p_{nti} - p_{n,(t-1),i}| \leq U_i^{\mathrm{ramp}} U_i^{\mathrm{prod}} (x_{nti} - x_{nti}^{\mathrm{up}}) + \max(L_i^{\mathrm{prod}}, U_i^{\mathrm{ramp}}) U_i^{\mathrm{prod}} x_{nti}^{\mathrm{up}} \qquad i \in \mathcal{H} \tag{3b}$$

$$p_{nti} \leq \rho_{nti} U_i^{\mathrm{prod}} x_{ni}^{\mathrm{op}} \qquad i \in \mathcal{R} \tag{3c}$$

$$a_{nt}^{\mathrm{e}} \leq D_{n\phi_t^{\mathrm{e}}}^{\mathrm{e}} \tag{3d}$$

The generation limits are imposed in constraints (3a). Constraints (3b) are the ramping constraints that limit the generation difference of thermal units in any consecutive time periods to a ramping limit in the right-hand-side of the equation. The generation pattern of VREs is determined by their hourly profile in the form of capacity factor; constraints (3c) limit the generation of VRE to hourly capacity factor (i.e. ρ_{nti}) of maximum available capacity (i.e. $U_i^{\mathrm{prod}} x_{ni}^{\mathrm{op}}$). Constraints (3d) state that the load shedding amount can not exceed demand. Note that we use the mapping ϕ_t^{e} to access the demand in the corresponding hour of a representative day.

Power Balance Constraints: For every $n \in \mathcal{N}^{\mathrm{e}}, t \in \mathcal{T}^{\mathrm{e}}$

$$\sum_{i \in \mathcal{P}} p_{nti} + \sum_{m \in \mathcal{N}^{\mathrm{e}}} \sum_{l \in \mathcal{L}_{nm}^{\mathrm{e}}} \mathrm{sign}(n-m) f_{\ell t}^{\mathrm{e}} + \sum_{r \in \mathcal{S}_n^{\mathrm{e}}} (s_{ntr}^{\mathrm{eDis}} - s_{ntr}^{\mathrm{eCh}}) + a_{nt}^{\mathrm{e}} = D_{n\phi_t^{\mathrm{e}}}^{\mathrm{e}} + d_n E^{\mathrm{pipe}} \kappa_n^{\mathrm{pipe}} + E^{\mathrm{cprs}} E^{\mathrm{pump}} \kappa_{nt}^{\mathrm{capt}} \tag{4}$$

Constraints (4) ensures that for each node and for each planning period the generation, the net flow, the net storage, and the load shedding amount should be equal to the net demand. The net demand is defined in the right-hand-side where the first term is the baseline demand, the second term is the electricity consumption by CO_2 pipelines and the last term is the electricity used by compressors. The notation $\mathrm{sign}(n-m)$ is the *sign* function that takes value -1 if $n < m$, value 1 if $n > m$, and 0 otherwise. We use this function to ensure that $f_{\ell t}^{e}$ appears with opposite signs (i.e., negative of positive signs) in the balance equations of the nodes connected by transmission line ℓ.

Network Constraints: For every $l \in \mathcal{L}^{\mathrm{e}}, t \in \mathcal{T}^{\mathrm{e}},$ and $n, m \in \mathcal{N}_\ell^{\mathrm{e}}$

$$|f_{lt}^{\mathrm{e}}| \leq I_\ell^{\mathrm{trans}} \qquad \text{if } \mathcal{I}_\ell^{\mathrm{trans}} = 1 \tag{5a}$$

$$|f_{lt}^{\mathrm{e}}| \leq U_\ell^{\mathrm{trans}} z_\ell^{\mathrm{e}} \qquad \text{if } \mathcal{I}_\ell^{\mathrm{trans}} = 0 \tag{5b}$$

$$|f_{\ell t}^{\mathrm{e}} - b_\ell(\theta_{mt} - \theta_{nt})| \leq M(1 - z_\ell^{\mathrm{e}}) \qquad \text{if } \mathcal{I}_\ell^{\mathrm{trans}} = 0 \tag{5c}$$

$$f_{\ell t}^{\mathrm{e}} = b_\ell(\theta_{mt} - \theta_{nt}) \qquad \text{if } \mathcal{I}_\ell^{\mathrm{trans}} = 1 \tag{5d}$$

$$\theta_{0,t} = 0 \tag{5e}$$

Flow for the existing transmission lines is limited by constraints (5a). Constraints (5b) limits the flow in candidate transmission lines only if it is already established (i.e., z_ℓ^{t}=1). Throughout the paper, we use M to denote a big number. Direct Current (DC) power flow constraints for candidate and existing transmission lines are respectively imposed in constraints (5c) and (5d). The phase angle for the reference node 0 is set in constraint (5e).

Storage Constraints: For every $n \in \mathcal{N}^{\mathrm{e}}, r \in \mathcal{S}_n^{\mathrm{e}}$

$$s^{\mathrm{eLev}}_{nt^{\mathrm{start}}_{\tau}r} = (1-\gamma^{\mathrm{loss}}_r)(s^{\mathrm{eLev}}_{n,t^{\mathrm{end}}_{\tau}r} - s^{\mathrm{rem}}_{n\tau r}) + \gamma^{\mathrm{eCh}}_r s^{\mathrm{eCh}}_{nt^{\mathrm{start}}_{\tau}r} - \frac{s^{\mathrm{eDis}}_{nt^{\mathrm{start}}_{\tau}r}}{\gamma^{\mathrm{eDis}}_r}, \qquad \tau \in \mathfrak{R} \tag{6a}$$

$$s^{\mathrm{eLev}}_{ntr} = (1-\gamma^{\mathrm{loss}}_r)(s^{\mathrm{eLev}}_{ntr}) + \gamma^{\mathrm{eCh}}_r s^{\mathrm{eCh}}_{ntr} - \frac{s^{\mathrm{eDis}}_{ntr}}{\gamma^{\mathrm{eDis}}_r} \qquad t \in \mathcal{T}^{\mathrm{e}} \backslash \{t^{\mathrm{start}}_{\tau} |\ \tau \in \mathfrak{R}\} \tag{6b}$$

$$s^{\mathrm{day}}_{n,\tau+1,r} = (1-24\gamma^{\mathrm{loss}}_r)s^{\mathrm{day}}_{n,\tau,r} + s^{\mathrm{rem}}_{n\Omega_{\tau},r}, \quad \tau \in \mathcal{T}^{\mathrm{g}} \backslash 365 \tag{6c}$$

$$s^{\mathrm{day}}_{n,1,r} = (1-24\gamma^{\mathrm{loss}}_r)s^{\mathrm{day}}_{n,\tau,r} + s^{\mathrm{rem}}_{n\Omega_{\tau},r}, \quad \tau = 365 \tag{6d}$$

$$s^{\mathrm{day}}_{n\tau r} = s^{\mathrm{eLev}}_{nt^{\mathrm{end}}_{\tau}r} - s^{\mathrm{rem}}_{n\tau r}, \quad \tau \in \mathfrak{R} \tag{6e}$$

$$s^{\mathrm{rem}}_{n\tau r} = 0, \quad \tau \in \mathfrak{R}, r \in \mathcal{S}^{\mathrm{sS}} \tag{6f}$$

$$s^{\mathrm{eCh}}_{ntr} \leq y^{\mathrm{eCD}}_{nr} \tag{6g}$$

$$s^{\mathrm{eCh}}_{ntr} \leq y^{\mathrm{eCD}}_{nr} \tag{6h}$$

$$s^{\mathrm{eLev}}_{ntr} \leq y^{\mathrm{eLev}}_{nr} \tag{6i}$$

Recall (see Fig. 1) that representative days are not necessarily consecutive; hence our formulation accounts for the carryover storage level between representative days, which is particularly important when modeling LDES. Li et al. [42] enforce the beginning and ending storage levels of each representative day to 50% of the maximum storage level. Here, we use a similar approach for short-duration batteries in which we time-wrap the beginning and ending hours of a day. That is, we assume the same charging state for the beginning and ending hours of a day, implicitly precluding energy carryover between representative days. For LDES, however, we use the method proposed in [37, 40] in which the unrestricted variable $s^{\mathrm{rem}}_{n\tau r}$ models the carryover from a representative day τ to the next.

Constraints (6a) model battery storage dynamics for the initial hours of each representative day. Constraints (6b) model the storage balance for the remaining hours. The energy transfer across two consecutive representative days is modeled via constraints (6c). The storage in the first and last representative days is related by constraints (6d). Constraint (6e) only applies to representative days and ensures that the storage at the beginning of a day is equal to the storage level at the last hour of the day minus the storage carryover. The storage carryover for short-duration batteries is prevented by constraints (6f). Finally, the charge/discharge limits on storage level are imposed in constraints (6g) to (6i). Analogous to similar studies on power system expansion [60, 42], we do not account for use-dependent storage capacity degradation.

Renewable Portfolio Standards (RPS):

$$\sum_{n\in\mathcal{N}^{\mathrm{e}}}\sum_{t\in\mathcal{T}^{\mathrm{e}}}\sum_{i\in\mathcal{R}} p_{nti} \geq L^{\mathrm{RPS}} \sum_{n\in\mathcal{N}^{\mathrm{e}}}\sum_{t\in\mathcal{T}^{\mathrm{e}}} D^{\mathrm{e}}_{n\phi^{\mathrm{e}}_t} \tag{7}$$

RPS is a policy constraint that requires a minimum share of the total electricity to be met by renewable sources and has been one of the core policies driving decarbonization efforts in many U.S. and global regions [34, 35]. In the model, constraint (7) requires that annual dispatched renewable generation must be at least a pre-specified fraction of total annual demand, specified by the parameter, L^{RPS}.

Resource Availability Constraints:

$$\sum_{n\in\mathcal{N}^{\mathrm{e}}}\sum_{i\in\mathcal{Q}} U_i^{\mathrm{prod}} x_{ni}^{\mathrm{op}} \le U_{\mathcal{Q}}^{\mathrm{prod}} \qquad \mathcal{Q}\in\mathcal{Q}' \tag{8}$$

We consider resource availability limits for the development of VRE sources. In comparison to thermal plants, the siting of renewable resources is a major challenge due to the relatively large land area footprint per MW, the spatial heterogeneity in their resource availability and land availability limits due to non-energy considerations such as preserving the natural landscape [34]. Therefore, constraint (8) limits the installed capacity of a certain set of power plants to their maximum availability limit. The parameter $\mathcal{Q}$ denotes a generation technology class for which there is a resource availability limit. These classes include solar, onshore wind, offshore wind, and nuclear and are represented by set $\mathcal{Q}'$. Note that each technology class can include multiple plant types. For example, nuclear technology can include existing and new nuclear plant types.

Carbon Capture and Storage (CCS) Constraints: For every $n\in\mathcal{N}^{\mathrm{e}}, t\in\mathcal{T}^{\mathrm{e}}$

$$\kappa_{nt}^{\mathrm{capt}} = \eta^{\mathrm{g}}\eta_i h_i p_{nti} \qquad i\in\mathcal{CCS} \tag{9a}$$

$$\kappa_{nt}^{\mathrm{capt}} \le \kappa_n^{\mathrm{pipe}} \tag{9b}$$

$$\sum_{n\in\mathcal{N}^{\mathrm{e}}}\sum_{t\in\mathcal{T}^{\mathrm{e}}} \kappa_{nt}^{\mathrm{capt}} \le U^{\mathrm{CCS}} \tag{9c}$$

The constraint (9a) computes the amount of captured carbon in gas-fired power plants equipped with CCS technology. Constraint (9b) determines the CO_2 pipeline capacity. Finally, constraint (9c) limits the total amount of captured CO_2 to the annual CO_2 storage capacity.

2.2 NG System Model

We now model the objective function and constraints pertaining to the NG system in the JPoNG.

Objective Function:

$$\min \sum_{l\in\mathcal{L}^{\mathrm{g}}} C_\ell^{\mathrm{pipe}} z_\ell^{\mathrm{g}} \tag{10a}$$

$$+ \sum_{k\in\mathcal{N}^{\mathrm{g}}}\sum_{\tau\in\mathcal{T}^{\mathrm{g}}} C^{\mathrm{ng}} g_{k\tau} \tag{10b}$$

$$+ \sum_{j\in\mathcal{N}^{s}} (C_j^{\mathrm{strInv}} x_j^{\mathrm{gStr}} + C_j^{\mathrm{vprInv}} x_j^{\mathrm{vpr}}) \tag{10c}$$

$$+ \sum_{j\in\mathcal{N}^{s}} \Big(C^{\mathrm{strFix}}(I_j^{\mathrm{gStr}} + x_j^{\mathrm{gStr}}) + C^{\mathrm{vprFix}}(I_j^{\mathrm{vpr}} + x_j^{\mathrm{vpr}})\Big) \tag{10d}$$

$$+ \sum_{k\in\mathcal{N}^{\mathrm{g}}}\sum_{\tau\in\mathcal{T}^{\mathrm{g}}} (C^{\mathrm{LCDF}} a_{k\tau}^{\mathrm{LCDF}} + C^{\mathrm{gShed}} a_{k\tau}^{\mathrm{ng}}) \tag{10e}$$

The objective function (10) minimizes the total investment and operating costs incurred in the NG system. The first term (10a) is the investment cost for establishing new pipelines. The second term (10b) is the cost of procuring NG from various sources to the system. For example, New England procures its NG from Canada and its adjacent states such as New York. The term (10c) and (10d) handle the investment

and FOM costs associated with NG storage, respectively. The last term (10e) captures the cost of using LCDF and NG load shedding.

NG Balance Constraint: For every $k \in \mathcal{N}^{\mathrm{g}}, \tau \in \mathcal{T}^{\mathrm{g}}$

$$\begin{aligned} & g_{k\tau} - \sum_{l \in \mathcal{L}_k^{\mathrm{gExp}}} f_{\ell\tau}^{\mathrm{g}} + \sum_{l \in \mathcal{L}_k^{\mathrm{gImp}}} f_{\ell\tau}^{\mathrm{g}} - \sum_{n \in \mathcal{A}_k^{\mathrm{e}}} f_{kn\tau}^{\mathrm{ge}} \\ & + \sum_{j \in \mathcal{A}_k^{s}} (f_{jk\tau}^{\mathrm{vg}} - f_{kj\tau}^{\mathrm{gl}}) + a_{k\tau}^{\mathrm{LCDF}} + a_{k\tau}^{\mathrm{g}} = D_{k\tau}^{\mathrm{g}} \end{aligned} \tag{11}$$

Constraints (11) state that for each node and period, the imported NG (i.e., injection), flow to other NG nodes, flow to power nodes, flow to and from storage nodes, load satisfied by LCDF, and unsatisfied NG load should add up to demand. Unlike power flow, the flow in pipelines is assumed to be unidirectional as it is typical for most long-distance transmission pipelines involving booster compressor stations [67]. We are ignoring the relatively small electricity demand associated with booster compression stations along the NG pipeline network.

Flow on Representative Days:

$$f_{kn\tau_1}^{\mathrm{ge}} = f_{kn\tau_2}^{\mathrm{ge}} \qquad \tau_1, \tau_2 \in \mathcal{T}^{\mathrm{g}} \text{ if } \Omega_{\tau_1} = \Omega_{\tau_2} \tag{12}$$

Given the set of representative days used to model power system operations (see Fig 1), constraint (12) ensures that gas consumption by the power system for all the days represented by the same day is identical.

Gas and LCDF Supply Constraints: For every $k \in \mathcal{N}^{\mathrm{g}}, \tau \in \mathcal{T}^{\mathrm{g}}$

$$L_k^{\mathrm{inj}} \le g_{k\tau} \le U_k^{\mathrm{inj}} \tag{13a}$$

$$a_{k\tau}^{\mathrm{LCDF}} + a_{k\tau}^{\mathrm{g}} \le D_{k\tau}^{\mathrm{g}} \tag{13b}$$

$$a_{k\tau}^{\mathrm{LCDF}} \le U_k^{\mathrm{inj}} \tag{13c}$$

The NG import limits are imposed in constraints (13a). The consumption of LCDF plus the load shedding is limited by constraints (13b) to the NG load. The alternative fuel LCDF can only be imported from nodes where gas can be supplied through the constraints (13c).

Flow Constraints: For every $\ell \in \mathcal{L}^{\mathrm{g}}, \tau \in \mathcal{T}^{\mathrm{g}}, j \in \mathcal{N}^{s}$

$$f_{\ell\tau}^{\mathrm{g}} \le I_{\ell}^{\mathrm{pipe}} \qquad \text{if } \mathcal{I}_{\ell}^{\mathrm{pipe}} = 1 \tag{14a}$$

$$f_{\ell\tau}^{\mathrm{g}} \le U_{\ell}^{\mathrm{pipe}} z_{\ell}^{\mathrm{g}} \qquad \text{if } \mathcal{I}_{\ell}^{\mathrm{pipe}} = 0 \tag{14b}$$

$$\sum_{k \in \mathcal{N}^{\mathrm{g}}: j \in \mathcal{A}_k^{s}} f_{kj\tau}^{\mathrm{gl}} = s_{j\tau}^{\mathrm{liq}} \tag{14c}$$

$$\sum_{k \in \mathcal{N}^{\mathrm{g}}: j \in \mathcal{A}_k^{s}} f_{jk\tau}^{\mathrm{vg}} = s_{j\tau}^{\mathrm{vpr}} \tag{14d}$$

The constraints (14a) and (14b) limit the flow between NG nodes for existing and candidate pipelines, respectively. The flow to liquefaction facilities is calculated in constraints (14c). Similarly, the flow out of vaporization facilities is modeled via constraints (14d).

Storage Constraints: For every $j \in \mathcal{N}^s, \tau \in \mathcal{T}^{\mathrm{g}}$

$$s_{j\tau}^{\mathrm{gStr}} = (1-\beta)s_{j,\tau-1}^{\mathrm{gStr}} + \gamma_j^{\mathrm{liqCh}} s_{j\tau}^{\mathrm{liq}} - \frac{s_{j\tau}^{\mathrm{vpr}}}{\gamma_j^{\mathrm{vprDis}}} \tag{15a}$$

$$s_{j\tau}^{\mathrm{vpr}} \leq I_j^{\mathrm{vpr}} + x_j^{\mathrm{vpr}} \tag{15b}$$

$$s_{j\tau}^{\mathrm{gStr}} \leq I_j^{\mathrm{gStr}} + x_j^{\mathrm{gStr}} \tag{15c}$$

Constraints (15a) ensure the storage balance. Constraints (15b) and (15c) limit the capacity of vaporization and storage tanks to their initial capacity plus the extended capacity, respectively.

2.3 Coupling Constraints

The following constraints are coupling constraints that relate decisions of the two systems.

$$\sum_{k \in \mathcal{A}_n^{\mathrm{e}}} f_{kn\tau}^{\mathrm{ge}} = \sum_{t \in \mathfrak{T}_\tau^{\mathrm{e}}} \sum_{i \in \mathcal{G}} h_i p_{nti} \qquad n \in \mathcal{N}^{\mathrm{e}}, \tau \in \mathfrak{R} \tag{16a}$$

$$\mathcal{E}^{\mathrm{e}} = \sum_{n \in \mathcal{N}^{\mathrm{e}}} \sum_{t \in \mathcal{T}^e} \sum_{i \in \mathcal{G}} w_t (1-\eta_i) \eta^{\mathrm{g}} h_i p_{nti}$$

$$\mathcal{E}^{\mathrm{g}} = \sum_{k \in \mathcal{N}^g} \sum_{\tau \in \mathcal{T}^g} \eta^{\mathrm{g}} (D_{k\tau}^{\mathrm{g}} - a_{k\tau}^{\mathrm{LCDF}} - a_{k\tau}^{\mathrm{g}})$$

$$\mathcal{E}^{\mathrm{e}} + \mathcal{E}^{\mathrm{g}} \leq (1-\zeta)(U_{\mathrm{emis}}^{\mathrm{e}} + U_{\mathrm{emis}}^{\mathrm{g}}) \tag{16b}$$

The first coupling constraints (16a) captures the flow of NG to the power network for each node and at each time period. The variable $\mathcal{E}^{\mathrm{e}}$ accounts for CO_2 emission due to the consumption of NG in the power system. The variable $\mathcal{E}^{\mathrm{g}}$ computes the emission from NG system by subtracting the demand from LCDF consumption and gas load shedding. The second coupling constraint (16b) ensures that the net CO_2 emissions associated with the power-gas system are below a pre-specified threshold value, which is defined based on a baseline emissions level. The first term is the emissions due to non-power NG consumption (i.e., NG consumption in the NG system such as space heating, industry use, and transportation). Since the model does not track whether LCDF is used to meet non-power NG demand or for power generation, the first term computes gross emissions from all NG use presuming it is all fossil and then subtracts emissions benefits from using LCDF.

Here we treat LCDF as a carbon-neutral fuel source [18], and thus the combustion emissions associated with its end-use are equal to the emissions captured during its production (see further discussion in Section 4). The second term captures the emission from NG-fired power plants. Alternatively, the emission constraints can only be applied to the power system as in [60] or separately applied to each system as in [67]. We evaluate the former approach by reformulating the emissions constraint to only consider power sector emissions and explore the impact of such a constraint in Section 4.

3 Case study and scenarios of interest

3.1 Case study

We apply the proposed JPoNGmodel to study joint planning of power and NG systems for a case study based on the New England region in the year 2050. We approximate

the region's power and NG networks using publicly available data (see Table 1) while recognizing the need to choose the model's spatial and temporal resolution to ensure reasonable computational run times. The resulting power system consists of 6 nodes where each node represents a state of New England. There are 23 existing and 40 candidate transmission lines between power network nodes. The power system has 5 existing and 7 new power plant types as described in Table 4 and Table 5 respectively. The existing types include gas-fired ("ng"), solar, onshore wind ("wind"), hydropower ("hydro"), and nuclear. New plant types include NG combustion turbine ("OCGT"), combined cycle ("CCGT"), combined cycle with carbon capture and storage technology ("CCGT-CCS"), utility-scale solar (solar-UPV), onshore wind ("wind-new"), offshore wind ("wind-offshore"), and nuclear ("nuclear-new"). The existing power plant capacity is modeled based on resources deployed as of 2016 and we model the flexibility to retire these assets if deemed economic. We consider Li-ion battery (4 hours) as the available short-duration storage and metal-air battery as representative of emerging long-duration storage technologies (roughly classified as those that are capable of storing energy over periods greater than 12 hours). The NG network consists of 18 NG nodes, and 7 SVL nodes. The NG nodes are connected via 17 existing and 54 candidate pipelines. The connections between NG nodes SVL nodes as well as NG nodes and power nodes are described in Fig. 2. Table 1 summarizes the major data inputs into the model for characterizing the electric and NG system and associated technologies, with further details available in the C.

3.2 Scenarios of interest

Coupling Cases: we evaluate the model for three scenario sets or *cases*, described in Fig. 3, that capture the following technology and policy aspects: a) whether emissions constraint is imposed on power system or the combined system, b) end-use electricity and NG demand profiles and c) availability of low-carbon substitutes for NG, namely LCDF. We model the availability of LDES in cases C3a and C3b. For each case, we evaluate the model under four CO_2 emissions reduction goals, which are defined based on relative sectoral reduction compared to 1990 levels for the case study of interest [27]. C.5 provides more details.

Per scenario dimensions shown in Fig. 3, case 1 (C1) consider JPoNG without LCDF or LDES and with emission constraint applied only on the power system. Hence, in C1, the Constraint (16b) is replaced with:

$$\mathcal{E}^{\mathrm{e}} \leq (1-\zeta) U^{\mathrm{e}}_{\mathrm{emis}}$$

Case 2 (C2) differs from C1 in that it considers a joint CO_2 emissions constraint for both systems as modeled by (16b), but still does not consider the availability of LCDF or LDES. Finally, case 3 (C3) is the complete model described in Section 2 in which a global emissions constraint and the possibility of LCDF import is considered. Additionally, we consider LDES in cases C3a and C3b with low and high estimates of investment and operational costs respectively.

emissions reduction goals: most New England states have goals for at least 80% economy-wide reduction in greenhouse gas (GHG) emission by 2050 vs. 1990 levels with some states targeting higher reductions [35]. Therefore, we consider four CO_2 emissions reduction scenarios relative to the 1990 baseline, with reduction levels ζ which include 80%, 85%, 90%, and 95%.

Demand characterization: electrification of end-use technologies is a key aspect of most regional economy-wide decarbonization plans and can greatly impact energy infrastructure investment and emission trajectories [47]. Heating electrification, in particular, is expected to play a key role in achieving emissions reduction goals in many parts of the US including New England [28]. Accordingly, we consider alternative end-use electricity and NG demand scenarios to study the impact of space heating electrification in residential and commercial building stock on the planning of power-NG infrastructure. We define business-as-usual (BAU) and high-electrification (HE) demand scenarios that assume electrification of space heating by replacing currently NG-fueled heaters with air- and ground-source heat pumps, albeit at different rates. The BAU scenario considers that minimum electrification is realized based on the current trend for the adoption of heat pumps. The HE scenario, however, accounts for the accelerated displacement of NG consumption and increasing power demand as a result of the mass adoption of heat pumps.

The power system demand in both HE and BAU scenarios is based on the 2050 hourly load profiles provided as part of the NREL's Electrification Future Study (EFS) Load Profile dataset [49]. The repository contains hourly load profiles for various electrification (Reference, Medium, High) and technology advancement (Slow, Moderate, Rapid) scenarios. The load profiles are provided for several years including 2050 and are further disaggregated by state, sector (residential, commercial, etc.), and subsectors (space heating and cooling, water heating, etc.). For BAU scenario, we consider the aggregated state-level hourly demand profile for the*Reference* electrification level with *Moderate* technology advancement.

To isolate the effect of heating electrification, we consider the HE demand scenario that differs from the BAU scenario in the enhanced electrification of the space heating subsector. Specifically, we replace the "space heating and cooling" subsector of the "Reference" and "Moderate" load profiles with "High" electrification and "Moderate" technology advancement load data, respectively. Once the space heating and cooling subsector are replaced, we aggregate based on sector and subsector to get state-level hourly electricity demand profile for the HE scenario. In the EFS scenarios, space heating comprises about 7% of the total power load in 2020, and its share increased slightly to 7.32% under *Reference* electrification level with *Moderate* technology advancement, and to 13.21% under *High* electrification level with *Moderate* technology advancement. In our modeled electricity demand scenario, the total load of BAU scenario is 128.64 TWh, of which 7.32% is incurred due to space heating. The load of the power system increase by 12.8% in HE scenario to 145.11 TWh with space heating making up 17.84 % of the total demand.

We estimate the NG load displacement due to space heating electrification by the EFS data [49], NREL's "End-Use Load Profiles for the U.S. Building Stock" project [52], and Energy Information Administration (EIA) [21]. The details of the estimation is given in C.4. Overall, space heating electrification is estimated to reduce the total NG load by 13.9%, from 5.15 $\times 10^7$ MMBtu in BAU to 4.44 $\times 10^7$ MMBtu in HE. Notice that the annual averaged efficiency of heat pumps is usually more than 100% [35], so the absolute reduction of space heating in the NG load is greater than the increase in electricity demand.




Figure 3: Technology cases, demand profiles, and CO_2 emissions reduction goals used in the computational experiments. LCDF = Low-carbon drop-in fuels. LDES = Long-duration energy storage.

3.3 Numerical experiments

All instances are implemented in Python programming language with Gurobi 9.5 solver and run the MIT Supercloud system with Intel Xeon Platinum 8260 processor with up to 48 cores and 192 GB of RAM [57]. We limit the CPU time to 10 hours for all instances by which point all models were solved to optimality with mixed integer gap of 0.1% or lower. We also set the value of L^{RPS} to 50% as suggested in [34], although as seen in the results, this constraint is non-binding.

We select the representative days based on the approach proposed in [10]. The method is developed for multivector energy systems such as the one we consider in this paper, and is based on physical topology and temporal demand pattern of the energy networks. We choose 30 representative days based on the results in B.1 (see Fig. 10). The model complexity increase with the number of representative days, generation and storage technologies, and spatiotemporal resolution of the networks. For the given number of representative days, the resulting problem has more than 0.44 million constraints and 0.6 million variables of which about 400 are integer variables.

4 Results

4.1 Joint planning with emissions limits on the power system

Fig. 4 highlights the system outcomes and costs for the joint planning model instance with emissions constraints only on the power system (i.e., C1). Fig. 4a is consistent with other studies on power system decarbonization – we find that tightening the emissions constraint leads to increased deployment of low-carbon generation options, primarily VRE capacity supplemented with Li-ion storage capacity as well as CCGT-CCS (90% CO_2 capture). Interestingly, all of the existing NG-fired power generation capacity is retained, albeit with much-reduced capacity utilization (3 to 7% for BAU, and 2 to 6% for HE scenario) as shown in Fig. 4b.

This result further implies that it is more cost-effective to retain existing NG-fired plants rather than build and sparingly utilize additional new gas-fired plants without CCS which incurs additional investment costs. On the other hand, increasing

electricity demand while meeting the same absolute emissions limit makes CCS-based power generation more cost-effective to deploy despite its higher heat rate and higher capital cost compared to CCGT without CCS. On average, this results in a 37% increase in NG consumption in the power sector between the HE and BAU scenarios. This increase is more than offset by the reduction in NG demand from buildings between BAU and HE scenarios for all emissions reduction goals except in the 95% where the total NG consumption in the HE scenario is 24% greater than the corresponding BAU scenario.

Across all the scenarios shown in Fig. 4, we see limited investment in network expansion costs, for both electricity and NG transport, corresponding to 2 and 3 new lines deployed respectively. In addition, since much of the increased electricity demand originates from electrifying heating services in buildings during winter months, the HE scenario also results in greater deployment of wind, both onshore and offshore, as compared to solar PV (Fig. 4b). This is explained by the much lower solar resource availability during winter time, with average hourly capacity factors for the modeled representative days during winter months (Dec-Feb) below 13%. Li-ion storage deployments are also reduced in the HE scenario vs. BAU scenario since it is generally cost-effective for short-duration energy storage applications (installed durations of storage are between 3 to 4.5 hours for scenarios shown in Fig. 4a) and strongly correlated with solar deployment. The additional electrification of building heat between HE and BAU scenarios results in modest increases in system costs ranging between 8-10% as shown in Fig. 4c.




Figure 4: Capacity, generation and system costs for C1 under BAU and HE scenarios and different emissions reduction goals

4.2 Impact of global emissions constraint (C2 vs. C1)

Here, we explore the impact of another layer of realism in energy infrastructure planning, namely limiting emissions from both NG and electricity systems in a combined manner that is consistent with mid-century economy-wide decarbonization goals.

Fig. 5 highlights the difference in power system capacity, electricity generation and total system cost between cases C2 and C1. Fig. 5a shows that a global emissions constraint disproportionately allocates emissions to meeting non-power NG demand while reducing NG-related emissions in the power system through increased VRE,

short-duration storage and CCGT-CCS capacity deployment. For example, in the HE scenario, VRE capacity and CCGT-CCS capacity on average increase in C2 relative to C1 by 56-70% and 73-1150% respectively, while total NG consumption by the power sector drops by 73-76%. Consequently, power sector emissions in C2 are 90-98% lower than sectoral emissions in C1 across the BAU and HE scenarios, which highlights the importance for emissions trading across sectors to meet the global emissions reduction goals.

Storage technologies act as complementary technologies to VREs and improve their utilization. Therefore the increase in renewable capacity leads to the greater deployment of battery energy storage (both power and energy capacity) across all scenarios in Fig. 5. The increased reliance on VRE also increases rated duration [2] of energy storage capacity deployed from 3.0-4.6 hours in C1 to 4.9-5.6 hours in C2.

Under the HE scenario, where non-power NG demand is reduced and so are the associated emissions, the model favors the deployment of additional CCGT-CCS based power generation that can be used to meet the higher electricity demand while still adhering to the imposed global emissions limits (Fig. 5b). Still, in the absence of alternative strategies such as the availability of LCDF for dealing with emissions from non-power NG consumption, the model is unable to meet a fraction of non-power NG demand (42-85% and 49-86% of non-power NG demand across the HE scenario and BAU scenario, respectively) while adhering to the imposed emissions limits. As Fig. 5c shows, due to heavy penalty imposed on non-served NG demand in the model (at a cost of 1000$/MMBtu), the associated load shedding costs dominate the cost differences between C2 and C1, where we also see that HE scenarios result in greater power system investment and reduced NG import cost as compared to the BAU scenario. It is important to note that not serving non-power NG demand at this scale is not a realistic scenario but we have included it as part of a systematic investigation of the impact of various supply and demand drivers impact power-NG infrastructure evolution.




Figure 5: Difference in capacity (a), generation (b), and system costs (c) between C1 and C2

[2] rated duration is defined as energy capacity times discharge efficiency divided by power capacity

4.3 Impact of low-carbon, drop-in fuels (C3 vs. C2) and its interplay with heating electrification

Here, we consider how the availability of LCDFs can impact power-NG infrastructure investment outcomes under carbon emissions constraints. LCDFs that are compatible with NG infrastructure can be sourced from multiple pathways including conversion of biomass [30, 43], valorization of waste feedstocks (e.g. municipal waste, manure, fats oils and greases, waster water treatment plants[41]), as well as production using electricity and renewable hydrogen in conjunction with CO_2, captured from the atmosphere [16]. Consistent with other energy system modeling studies [18, 33], we assume that LCDF costs four times more than fossil NG at 20$/MMBtu and it is a carbon-neutral fuel in the sense that the combustion emissions associated with its end-use are equal to the atmospheric CO_2 emissions captured during its production. These estimates are within the range of life cycle carbon footprint and costs reported for LCDFs compatible with NG infrastructure. For instance, recent life cycle analysis studies suggest that LCDF sourced from waste feedstocks could have negative to slightly positive life cycle GHG emissions [41].

Fig. 6 shows that LCDF makes it possible to fully serve electricity and NG demand across all the emissions and demand scenarios, as seen by a reduction in NG load shedding related costs between C3 and C2. Compared to C2, C3 sees increased generation from existing NG capacity (without CCS) and nuclear capacity (Fig. 6b) where the former operates in a flexible manner to balance VRE integration and thus also enables increased utilization of the less flexible nuclear generation fleet (see Table 5 for flexibility parameters). This operational pattern is evident in Fig. 7a and 7b that highlights the dispatch of the power system during the modeled representative days during winter months for BAU and HE scenarios, respectively.

Although the generation mix for both scenarios contains a significant amount of VREs (see B.2, Fig. 11), it is still necessary to dispatch from other plants. For both scenarios, the dispatch of "hydro" and "nuclear" are relatively constant (though some 'nuclear" plants are shut down sporadically). This is consistent with the observation made in [60] that emphasizes the greater value of base load low carbon generation like nuclear. Simultaneously, the increased utilization of existing assets results in the reduction of installation of VRE generation, Li-ion storage as well as CCGT-CCS capacity. The latter is particularly important to serve electricity demand during peak consumption periods (see Fig. 7) and results in an interesting observation where the installed CCGT-CCS capacity has higher utilization in C3 relative to C2 (28-47% vs. 6-7%). This finding can be explained by the availability of a carbon-neutral fuel like LCDF in C3 vs. C2 as illustrated in Fig. 7a and 7b.

Electrification of the buildings sector increases electricity demand in the winter months that results in a shift in the power system capacity mix to favor resources capable of producing electricity during those periods, namely wind generation and CCGT-CCS instead of solar PV (Fig. 8). As noted in section 4.2, Li-ion storage deployment complements solar PV deployment as compared to wind deployment and this explains why we see lesser Li-ion storage in the HE scenario. The reduction in non-power NG demand in the HE scenario as compared to BAU scenario facilitates use of additional NG in conjunction with CCS, in balancing the power system and therefore reduces the need to rely on more expensive fuels like LCDF for emissions abatement. Fig. 7b illustrates this point by highlighting a greater role for CCGT-CCS during





Figure 6: Difference in capacity (left) and generation (right) between C2 and C3

periods of peak electricity demand in the HE vs. BAU scenario. Across the emissions constraint scenarios, increasing end-use electrification results in 13-19% lower overall LCDF use, while increasing overall NG consumption (both power and non-power) by 10-20% and increasing power system investment costs by 14-21%. Overall, the system cost for the HE scenario in C3 are on average 0.13% lower compared to the BAU scenario suggesting the importance of electrification as a cost-effective mechanism for deep decarbonization of energy systems.



(a) (b)

Figure 7: Hourly mix for a typical winter week in C3, BAU (left) and HE (right) scenarios with $\zeta = 80\%$. A Typical winter week is a set of seven representative days in winter months, so these days are not necessarily contiguous.

4.4 Impact of Long-duration Energy Storage (C3a-b vs. C3)

LDES is another emerging technology that is expected to play a major role in the energy transition [60] and is typically characterized by much lower energy capital costs and round-trip efficiencies and higher power capital costs compared to Li-ion storage systems [35].

While there are many alternative configurations of LDES systems being developed based on thermal, electrochemical, chemical and mechanical energy storage concepts,




Figure 8: Difference in capacity (a) and generation (b) between BAU and HE of C3. Fig (c) shows system cost components for both BAU and HE scenarios of C2

here we evaluate the impact of LDES technology participation in deeply decarbonized energy systems based on plausible low and high cost and performance estimates for aqueous metal-air battery sourced from the literature [35]. For the HE demand scenario, Fig. 9 compares outcomes between C3 with C3a and C3b, where the latter two correspond to scenarios with low (3a) and high (C3b) cost estimates for metal-air battery.

Fig. 9a and Fig. 9b show that the availability of LDES generally shifts the power system portfolio to rely on wind over CCGT-CCS, solar PV and short-duration storage, with the most pronounced impacts seen in the low-cost LDES scenario. Importantly, the adoption of LDES improves the capacity utilization of wind and solar generation. The reduced use of NG in the power system resulting from LDES adoption reduces the extent of coupling between electricity and NG infrastructure and also reduces the reliance on expensive fuels like LCDF for meeting non-power NG demand as depicted in Fig. 9c. Collectively, these factors result in LDES contributing to system cost reductions ranging between 3.8-4.5% in the low-cost LDES scenario and 0.2-1.5% in the high-cost LDES scenario shown in Fig. 9.

5 Discussion and Concluding Remarks

Deep decarbonization of energy systems require infrastructure planning whose scope need to span across sectors and infrastructure for different vectors while considering increasing spatial and temporal variability of energy supply and demand and cross-sectoral interactions. In this paper, we developed an integrated optimization model for joint planning of power and NG infrastructure that considers intra-annual operation of these systems as well as a range of low-carbon energy technologies such as VRE generation, short and long-duration storage, LCDFs, power generation with CCS. Importantly, our model allows for different temporal resolutions of operation for electric and NG infrastructure and facilitates the assessment of various coupling mechanisms




Figure 9: Difference in capacity (left), generation (middle) and costs (rights) between HE scenarios of C3 for metal-air with *low* and *high* cost estimates

between the two infrastructures including, emissions reduction goals, building stock electrification, as well as use of NG and LCDFs across the two sectors.

This framework reveals a number of key observations pertaining to deep decarbonization of energy systems and the interplay of technology and policy levers. **First**, similar to other studies on power system decarbonization [36], we find that cost-effective pathways for deep decarbonization of energy systems require aggressive expansion of VRE and energy storage systems, with a specific emphasis on onshore and offshore wind generation for the New England region.

Second, a global emissions reduction viewpoint, enabled by our multi-vector modeling formulation, points to the cost-effectiveness of a disproportionate reduction in emissions from the power system rather than other sectors using NG for final energy. This is primarily due to the relatively low abatement cost resulting from the projected costs of VRE electricity generation options. For example, in both reference and high electrification scenarios of C3, gross emissions from the power system represent 15-30% and 21-43% of the emission budget, respectively.

Third, across the scenarios we see reliance on a portfolio of strategies for system balancing and emissions reduction including VRE complemented with short and long-duration storage, dispatchable generation using both fossil fuel and more expensive LCDFs as well as CCS, VRE curtailment and non-power NG demand reduction via electrification. The results also highlight a limited expansion of NG infrastructure, with at most one to three pipelines added across the scenarios, suggesting that any significant investments in the NG infrastructure may not be economical under future carbon-constrained scenarios.

Fourth, our modeling approach also helps in evaluating the relative cost impact of demand and supply-side measures. For the modeled high electrification levels, which reduce non-power NG demand and increases the share of renewable generation sources, system costs are generally lower or similar compared to the BAU demand scenario. Counterintuitively, under the global emissions constraints and with the availability of LCDFs, the total NG consumption in the HE scenario is 10-20% greater in C4 than the corresponding BAU scenario, where the increased NG consumption is directed towards CCS-based power generation. Furthermore, our analysis shows that the availability of low-cost LDES can considerably reduce the total system cost.

Finally, we observe that for either electrification scenario, the total cost in many instances is in the same range suggesting that other metrics considered here such as the share of renewable sources, infrastructure expansion cost, and the share of capital investments as well those not considered here, such as land impacts, reliability measures, and robustness to inter-annual variations, might be better criteria to distinguish the importance of each pathway.

In terms of next steps, the proposed modeling framework has certain limitations and can be refined in multiple ways. First, the supply patterns for gas and LCDF can be better described by considering their spatial temporal availability and price volatility as a function of consumption (e.g. similar to price volatility seen for NG [22]). Second, the extent of electrification of non-power NG demand is relatively low compared to state-level policy ambitions and future work could focus on developing granular demand scenarios for building, transportation and industry that are aligned with stated policy goals and evaluating their supply-side impacts. Third, our model does not model the strategic retirement of NG pipeline & storage infrastructure assets which could form an important component of NG system's cost if the displacement of gas with electricity is significant.

Apart from application details, future work can identify sources of uncertainty and include stochasticity in the modeling framework. Furthermore, the resiliency of the planning outcomes toward inter-annual demand and supply variations as well as extreme weather conditions is another direction to pursue. Finally, future studies can leverage decentralized planning approaches to better reflect the energy planning process that is usually carried out by multiple stakeholders in each energy system who usually have competing interests and sometimes opposing objectives.

A Nomenclature

Sets	
$\mathcal{N}^{\mathrm{e}}$	Power system nodes
$\mathcal{P}$	Power plant types
$\mathcal{R} \subset \mathcal{P}$	VRE power plant types
$\mathcal{G} \subset \mathcal{P}$	gas-fired plant types
$\mathcal{CCS} \subset \mathcal{P}$	gas-fired plant types with carbon capture technology
$\mathcal{H} \subset \mathcal{P}$	Thermal plant types
$\mathcal{Q} \subset \mathcal{P}$	Technology with a resource availability limit
$\mathcal{Q}'$	Set of technologies with resource availability limits
$\mathcal{T}^{\mathrm{e}}$	Index set of representative hours for power system
$\mathfrak{R}$	Representative days
$\mathfrak{T}^{\mathrm{e}}_{\tau}$	Hours in $\mathcal{T}^{\mathrm{e}}$ that are represented by day τ
$t^{\mathrm{start}}_{\tau}, t^{\mathrm{end}}_{\tau}$	First and last hour in $\mathfrak{T}^{\mathrm{e}}_{\tau}$
$\mathcal{L}^{\mathrm{e}}$	Existing and candidate transmission lines
$\mathcal{L}^{\mathrm{e}}_{nm}$	Existing and candidate transmission lines
$\mathcal{S}^{\mathrm{eS}}_{n}$	Short-duration energy storage system types
$\mathcal{S}^{\mathrm{eL}}_{n}$	Long-duration energy storage system types
$\mathcal{S}^{\mathrm{e}}_{n}$	All energy storage systems types
$\mathcal{A}^{\mathrm{g}}_{n}$	Adjacent NG nodes for node n

	between node n and m
$\mathcal{N}^{\mathrm{g}}, \mathcal{N}^{s}$	NG and SVL nodes
$\mathcal{T}^{\mathrm{g}}$	Days of the planning year
$\mathcal{A}_k^s$	Adjacent SVL facilities of node k
$\mathcal{L}^{\mathrm{g}}$	Existing and candidate pipelines
$\mathcal{L}_k^{\mathrm{gExp}}$	Existing and candidate pipelines starting from node k
$\mathcal{L}_k^{\mathrm{gImp}}$	Existing and candidate pipelines ending at node k

Indices

n, m	Power system node
k	NG system node
j	SVL facility node
i	Power generation plant type
r	Storage type for power network
ℓ	Electricity transmission line or gas pipeline
t	Time step for power system's operational periods
τ	Time step for NG system's operational periods

Annualized Cost Parameters

C_i^{inv}	CAPEX of plants, [$/plant]
C_i^{dec}	Plant decommissioning cost, [$/plant]
C_ℓ^{trans}	Transmission line establishment cost, [$/line]
C_r^{EnInv}	Storage establishment energy-related cost, [$/MWh]
C_r^{pInv}	Storage establishment power-related cost, [$/MW]
C_ℓ^{pipe}	Pipelines establishment cost, [$/line]
C_j^{strInv}	CAPEX of storage tanks at SVLs, [$/MMBtu]
C_j^{vprInv}	CAPEX of vapor. plants at SVLs, [$/MMBtu/hour]

Annual Costs

C_i^{fix}	Fixed operating and maintenance cost (FOM) for plants, [$]
C_r^{EnFix}	Energy-related FOM for storage, [$/MWh]
C_r^{pFix}	Power-related FOM for storage, [$/MW]
C_j^{strFix}	FOM for storage tanks, [$/MMBtu]
C_j^{vprFix}	FOM for vaporization plants, [$/MMBtu/hour]

Other Cost Parameters

C_i^{var}	Variable operating and maintenance cost (VOM) for plants, [$/MWh]
C_i^{startUp}	Start-up cost for plants, [$]
C^{eShed}	Unsatisfied power demand cost, [$/MWh]
C_i^{fuel}	Fuel price for plants, [$/MMBtu]
C^{ng}	Fuel price for NG, [$/MMBtu]
C^{LCDF}	Price of LCDF, [$/MMBtu]

C^{gShed}	Unsatisfied NG demand cost [$/MMBtu]

Other Parameters for the Power System

ρ_{nti}	Capacity (availability) factor for renewable plants
D^{e}_{nt}	Power demand, [MWh]
h_i	Heat rate, [MMBtu/MWh]
b_ℓ	Susceptance of line $\ell \in \mathcal{L}^{\text{e}}$
η_i	Carbon capture rate, [%]
U^{prod}_i	Nameplate capacity, [MW]
L^{prod}_i	Minimum stable output, [%]
U^{ramp}_i	Ramping limit, [%]
$\gamma^{\text{eCh}}_r, \gamma^{\text{eDis}}_r$	Charge/discharge rate for storage
γ^{loss}_r	hourly self-discharge rate for storage
I^{trans}_ℓ	Initial capacity for transmission line ℓ, [MW]
U^{trans}_ℓ	Upper bound for capacity of transmission line ℓ, [MW]
$\mathcal{I}^{\text{trans}}_\ell$	1, if trans. line ℓ exists; 0, otherwise
I^{num}_{ni}	Initial number of plants
$U^{\text{e}}_{\text{emis}}$	Baseline emission of CO_2 in 1990 from generation consumption, [ton]
U^{CCS}	Total annual carbon storage capacity, [ton]
L^{RPS}	Renewable Portfolio Standard (RPS) value
d_n	Distance between node n and CO_2 storage site
E^{pipe}	Electric requirement for CO_2 pipeline operations [MWh/mile/ton/hour]
E^{pump}	Electric requirement for compression of CO_2
E^{cprs}	Number of compressors required in the pipeline from node n to the storage site pipelines [MWh/ton/hour]
$U^{\text{prod}}_{\mathcal{Q}}$	Production capacity for set of plants $\mathcal{Q} \subset \mathcal{P}$, [MW]
ζ	emissions reduction goal
w_t	Weight of the representative period t
ϕ^{e}_t	Mapping of representative period t to its original period in the time series

Other Parameters for the NG System

$D^{\text{g}}_{k\tau}$	NG demand, [MMBtu]
η^{g}	Emission factor for NG [ton CO_2/MMBtu]
U^{inj}_k	Upper bound for NG supply, [MMBtu]
γ^{liqCh}_j	Charge efficiency of liquefaction plant
γ^{vprDis}_j	Discharge efficiency of vaporization plant
β	Boil-off gas coefficient
I^{pipe}_ℓ	Initial capacity for pipeline ℓ, [MMBtu/day]
U^{pipe}_ℓ	Upper bound capacity for pipeline ℓ, [MMBtu/day]
$\mathcal{I}^{\text{pipe}}_\ell$	1, if the pipeline ℓ exists; 0, otherwise
I^{gStr}_j	Initial storage capacity, [MMBtu]
I^{vpr}_j	Initial vaporization capacity, [MMBtu/d]
I^{liq}_j	Initial liquefaction capacity, [MMBtu/d]
I^{store}_{kj}	Initial capacity of storage facility

$U^{\mathrm{g}}_{\mathrm{emis}}$	Baseline emission of CO_2 in 1990 from non-generation consumption, [ton]
Ω_n	representative day for day n

Investment Decision Variables

$x^{\mathrm{op}}_{ni} \in \mathbb{Z}^+$	Number of available plants
$x^{\mathrm{est}}_{ni} \in \mathbb{Z}^+$	Number of new plants established
$x^{\mathrm{dec}}_{ni} \in \mathbb{Z}^+$	Number decommissioned plants
$y^{\mathrm{eCD}}_{nr} \in \mathbb{R}^+$	Charge/discharge capacity of storage battery
$y^{\mathrm{eLev}}_{nr} \in \mathbb{R}^+$	Battery storage level
$z^{\mathrm{e}}_{\ell} \in \mathbb{B}$	1, if transmission line ℓ is built; 0, otherwise
$z^{\mathrm{g}}_{\ell} \in \mathbb{B}$	1, if pipeline ℓ is built; 0, otherwise

Other Decision Variables for Power System

$p_{nti} \in \mathbb{R}^+$	Generation rate, [MW]
$x_{nti} \in \mathbb{R}^+$	Number of committed plants
$x^{\mathrm{down}}_{nti} \in \mathbb{R}^+$	Number of plants shut-down
$x^{\mathrm{up}}_{nti} \in \mathbb{R}^+$	Number of plants started up
$f^{\mathrm{e}}_{\ell t} \in \mathbb{R}$	Flow rates, [MW]
$\theta_{nt} \in \mathbb{R}$	Phase angle
$s^{\mathrm{eCh}}_{ntr}, s^{\mathrm{eDis}}_{ntr} \in \mathbb{R}^+$	Storage charged/discharged, [MW]
$s^{\mathrm{eLev}}_{ntr} \in \mathbb{R}^+$	Storage level, [MWh]
$s^{\mathrm{rem}}_{n\tau r} \in \mathbb{R}$	Storage carry over during day τ for storage type $r \in \mathcal{S}^{\mathrm{sL}}$
$s^{\mathrm{day}}_{n\tau r} \in \mathbb{R}^+$	Storage level at the beginning of day τ for storage type $r \in \mathcal{S}^{\mathrm{sL}}$
$\kappa^{\mathrm{capt}}_{nt} \in \mathbb{R}^+$	Captured CO_2 [ton/h]
$\kappa^{\mathrm{pipe}}_{n} \in \mathbb{R}^+$	CO_2 pipeline capacity [ton/h]
$a^{\mathrm{e}}_{nt} \in \mathbb{R}^+$	Amount of load shedding, [MWh]
$\mathcal{E}^{\mathrm{e}}$	Total emission from power system

Other Decision Variables for NG System (all in MMBtu)

$x^{\mathrm{gStr}}_{j} \in \mathbb{R}^+$	Installed additional storage capacities
$x^{\mathrm{vpr}}_{j} \in \mathbb{R}^+$	Installed additional vaporization capacities
$f^{\mathrm{g}}_{\ell\tau} \in \mathbb{R}^+$	Flow rates
$f^{\mathrm{ge}}_{kn\tau} \in \mathbb{R}^+$	Flow rates from NG nodes to power nodes
$f^{\mathrm{gl}}_{kj\tau} \in \mathbb{R}^+$	Flow rates from node NG nodes to liquefaction plants
$f^{\mathrm{vg}}_{jk\tau} \in \mathbb{R}^+$	Flow rates from vaporization plants to NG nodes
$g_{k\tau} \in \mathbb{R}^+$	NG supply (injection)
$s^{\mathrm{gStr}}_{j\tau} \in \mathbb{R}^+$	Storage capacities
$s^{\mathrm{vpr}}_{j\tau}, s^{\mathrm{liq}}_{j\tau} \in \mathbb{R}^+$	Vaporization and liquefaction amounts
$a^{\mathrm{g}}_{k\tau} \in \mathbb{R}^+$	Amount of load shedding
$a^{\mathrm{LCDF}}_{k\tau} \in \mathbb{R}^+$	Amount of LCDF consumption
$\mathcal{E}^{\mathrm{g}}$	Total emission from NG system

B Additional Results

B.1 Number of Representative Days

Fig 10 shows the total system, power system, NG system costs as well as cost of establishing new plants for different number of representative days. The cost values fluctuate in lower number of representative days, but tend to stabilize after 22 days. The total system cost converges after 39 days, so we run all instances with 40 representative days.




Figure 10: Scaled values for total system cost, power system cost, and NG system cost for different number of representative days

B.2 Generation Mix

The generation mix of all cases for the both scenarios are shown in Fig. 11.




Figure 11: Generation mix of C1, C2, and C3

C Problem Data

This section provides a description of the processes by which we obtained parameters for both networks for the New England Case study. We start with power system and explain the data preparation process. We then expound on steps we took to construct the natural gas (NG) network and associated data inputs. In this study our region is New England, but we want to emphasize that the modeling framework and the solution approach is applicable to other regions.

C.1 Power Network Topology

Our parameters for the power network is based on the *US Test System* developed by *Breakthrough Energy* [69]. The dataset contains a high-temporal and spatial resolution load and variable renewable energy (VRE) data for the entire US "base_grid" in year 2016. It also contains load data for year 2020, and projections for year 2030. The dataset provides a test system with detailed information for existing buses, substations, plants, branches as well as generation profile for existing renewable energy capacity, including solar and land-based wind. We consider the base_grid and start by filtering the data for New England region which corresponds to zone 1 to 6 in the dataset. We then filter for high voltage buses [12] i.e. those with voltage greater than or equal to 345kV. This process results in 188 nodes each of which representing a high-voltage bus. The filtering process results in 192 transmission lines between them indicating that each node is connected to approximately one other node on average. We use this information and the possible fact that some of the 188 nodes correspond to the same geographical location, in creating candidate transmission lines. Specifically, we assume that each candidate transmission line connects a node to its nearest one with non-zero distance. We then estimate the susceptance and maximum flow of each candidate transmission line by a linear regression fitted on the parameters available for the existing lines.

Once the 188-node power network is constructed, we aggregate buses by their corresponding state and remove the transmission lines between buses of the same state. Aggregating nodes for zonal level is a common practice in the literature of capacity expansion for energy system (see, for example, [60, 42, 72]). Reducing the number of nodes improves the scalibility of the problem and increases the interpretability of the solution. For our case study, the aggregation process resulted in a network with 6 nodes (one node for each state in the New England region), and 63 transmission lines out of which 40 are candidate lines. Notice that there can be multiple transmission lines with varying characteristics (i.e. maximum flow, susceptance, and distance) between nodes.

C.2 Power System Data

The "base_grid" data contains power plants information at each bus. We first remove power plants types of "dfo" (distillate fuel oil) and "coal" as their share is not substantial in the base year and there are plans to completely phase out those plant types by 2050. We then calculate the existing generation capacity at each bus from each plant type by considering "in-service" plants with generation capacity greater than 10MW for "ng" (i.e gas-fired plants) and "nuclear" plants, and greater than 2MW for VREs. Note that "ng" plants are treated as a lump since the Breakthrough Energy data set does not provide a breakdown between capacity of combined cycle and open-cycle plants. We then assign each plant to the nearest node, and eventually aggregate the generation capacity of each plant type for each of the 6 nodes. Table 4 and 5 present the technical assumptions for the existing and new power plants used in this study. Most of the parameters for the existing plants are derived from the Breakthrough Energy data set [9]. The footnote text in Table 4 presents details on the value of each parameter. The technical assumptions for new plants is largely derived from

National Renewable Energy Laboratories (NREL) Annual Technology Baseline 2021 edition (ATB 2021) for year 2045 [48]. Values of parameters that are not available in ATB 2021 are adopted from the corresponding existing power plants or obtained from Sepulveda et al. [60]. The details of each parameter is provided in the footnote text in Table 5.

We incorporate regional capital cost multipliers provided in *ReED Model Documentation* [12], summarized in Table 9, to distinguish between the capital cost of new power plants in the different model regions. These multipliers are applied to the baseline capital costs reported in Table 5. Subsequently, the capital costs are annualized to be included in the single-stage investment planning model using the following formula for the annual cost fraction: $\frac{\omega}{1-(\frac{1}{1+\omega})^{lt}}$. Here, lt is the lifetime of the specific technology and ω corresponds to the discount rate of 7.1%. Thus, the annualized CAPEX for new power plants is obtained by multiplying the CAPEX to the annual cost fraction and regional multiplier. For every other investment costs (i.e. transmission lines, pipelines, storage etc.) we only multiply the CAPEX to annual fraction factor to get the annualized CAPEX.

To obtain capacity factors (CFs) for existing renewables (solar, wind, and hydro) capacity, we used the hourly generation data available in the Breakthrough Energy data set, specifically, the *base_line* data [9]. We obtain the capacity factors of solar and wind plants by dividing their hourly generation to their nameplate capacity. The CFs at each node is obtained by taking average over the CFs of the existing solar and wind plants belonging to that node. For the new solar and wind plants, we use the GenX data set which is obtained from the Future of Storage Study modeling of the U.S. Northeast [37, 35]. The data set provides solar and wind capacity factors for 6 zones of US Northeast in year 2045 for a 7 weather conditions corresponding to years 2007 to 2013. For each zone, the dataset contains 3 bins of wind and 2 bins of solar CF profiles reflecting the variation in VRE sites across each zone. Among the 6 zones used in the Future of Storage study modeling of the U.S. Northeast [35], zone 1, 2, and 3 covers the New England region such that zone 1 represents Maine (ME), zone 2 corresponds to Massachusetts (MA), Vermont (VT), New Hampshire (NH) and Rhode Island (RI), and zone 3 represent Connecticut (CT). To use the Future of Storage study data for our 6-zone representation of the New England region, we made the assumption that the VRE capacity factors for new plants for MA, VT, NH, and RI for technology (solar, onshore wind) are the same. This assumption will be revisited in the future. Further, we only allowed for offshore wind deployment in MA and CT.

Energy Storage is likely to be an essential part of the future power systems dominated by VRE supply. While many storage technologies are proposed or are under development, we only model the potential deployment of Li-ion battery, given its commercial availability and available cost projections. We sourced Li-ion battery cost and performance assumptions from [48], as summarized in Table 6. Other economic and technical assumptions for the power network are presented in Table 7 and Table 8. Figure 12 illustrates a simplified power network.

General Note about Tables: The column of tables shows the associated symbol in the formulation. The notations with *tilde* are *crude* cost values whose manipulated forms (e.g. regional update, annualization) are used in the numerical model. For example, $\tilde{C}_i^{\text{inv}}$ in Table 5 denote the value of C_i^{inv} before annualization.

C.3 NG Network Topology and Data

NG network consist of two types of nodes: 1) NG nodes: each NG node has an injection capacity and load; 2) SVL nodes: each SVL node consist of Storage, Vaporization, and Liquefaction (SVL) facilities each with their own capacity. We construct the NG network based on the data available on Energy Information Administration (EIA) website [21]. The pipeline data provide information on the counties connected through a uni-directional pipeline




Figure 12: Simplified power system network. Each edge between nodes represents multiple transmission lines. The thickness of each edge is proportional to the summation of maximum flow of lines they represent.

as well as the capacity of each connecting pipeline. We first filter all the pipelines that connect counties inside the region or connect a county outside of the New England to a county inside. We consider counties inside the New England region as the NG network nodes and pipelines between them as edges. We then consider pipelines connecting nodes to outside counties and calculate the maximum injection capacity (i.e. supply) for each node. This process results in a 18 nodes and 17 NG pipelines to make up the existing NG network. Note there is only at most one pipeline between each pair of nodes, however, the formulation is for the general case where ,similar to the power system, there can be multiple pipelines between NG nodes.

NG is usually stored in its liquefied form called LNG. LNG storage usually involves three types of facility:

- Storage tank: smaller tanks located inland that are filled by truck supply from the import facilities and are used to regulate pressure of the gas system – these facilities have tanks and vaporization facilities [44]. Capacity of a storage facility is measured in energy/volume level (i.e. MMBtu or MMScf)

- Liquefaction: a facility that receives NG from pipeline system and liquefies it at temperature around -162 Celsius [44, 46]. Capacity of liquefaction facility is measured in terms of flow rate (i.e. MMBtu/period or MMScf/period)

- Vaporization: The facility evaporates the LNG leaving the storage facility by warming it with sea water or air to produce gas that is injected into the pipeline network. At certain areas, trucks are used to transport LNG from a major storage site to a smaller storage site where they are later evaporated [44]. For the ease of transportation, storage and vaporization facilities are build at the same location. Capacity of vaporization facility is measured in terms of flow rate (i.e. MMBtu/day or MMScf/day).

The simplified topology of the NG system is depicted in Figure 13.

We construct the SVL network based on the the data provided in [3]. We assume that all three facilities are located at the same location. There are currently 5 liquefaction facilities and 43 storage in New England. The exact location of these facilities are not provided, but the




Figure 13: Simplified NG network. Each edge represents a single pipelines between nodes. The thickness of each edge is proportional to the maximums capacity of the pipeline. The connections between SVL nodes and NG nodes is not shown here for simplicity of the plot.

source provides a map of the region showing the approximate locations of storage tanks. Given that there are only 5 liquefaction facilities, we first cluster storage tanks into 5 location and assume a liquefaction and a vaporization facility at each location. This assumption effectively approximates the practice of moving LNG via trucks from the centralized liquefaction facilities to the distributed storage (and vaporization) facilities. Each of these locations is a node in the SVL network. The total liquefaction, vaporization and storage capacities for the New England region is given in [3]. To account for variation in the capacities, we unevenly distribute these capacities over 5 SVL nodes shown in Figure 13. Moreover, there are two LNG import locations in New England, each having storage and vaporization facilities with given capacities. We consider these two locations as SVL nodes with no liquefaction capacity, resulting in 7 SVL nodes in total. The transportation of NG between different nodes is assumed to be realized as follows:

- NG node to NG node: The existing pipelines between NG nodes is provided in [21]. We assume that there is a candidate pipeline between each node and 3 of its closest nodes, resulting in 54 candidate pipelines. The capacity of candidate pipelines are set to the average capacity of the existing pipelines.

- NG to power node: The number of NG nodes is three times more than power nodes (6 nodes in power system vs. 18 nodes in NG system). We use this fact to assume that each power node is already connected to three nearest NG node through distribution pipelines. The pipeline capacity available to these neighboring NG nodes thus limits the amount of flow between NG and power nodes, so we assume that the connection between NG and power nodes has no capacity limits.

- NG and SVL nodes: We assume that each NG node is already connected to two nearest SVL node through two sets of pipelines. The first set carries NG from NG node to the liquefaction facility in a SVL, and the second set of pipelines transport NG from vaporization facility in a SVL to a NG node.




Figure 14: Three types of nodes in the formulation including power, NG, and storage-vaporization-liquefaction (SVL) nodes. Note that two pairs of SVL and NG nodes share the same location. The connections are not shown.

Figure 2 shows our assumption about connection between different nodes. The parameters for NG system are presented in Table 10. Figure 14 shows the dispersion of power, NG, and SVL nodes in the New England region.

C.4 Electricity and NG Demand Scenarios

We use NREL's Electrification Future Study Load Profile dataset [49] data for power system in both high and reference electrification scenarios.

The load for NG is generally disaggregated into five sectors including residential, commercial, industrial, vehicle fuel consumption, and electric power customers [21]. The consumption for electric power consumers is a decision variable in our model, so our input for NG demand involves the NG demand in the remaining four sectors. Our approximation of daily NG consumption profile for residential and commercial sector under various electrification scenarios is based on NREL's "End-Use Load Profiles for the U.S. Building Stock" project [52] and NREL's "Electric Technology Adoption and Energy Consumption" [51]. The former project consist of ResStock and ComStock projects that are analysis tools to help users better understand the residential and commercial building stock energy use. Each project has a website that allows users to get state-level consumption of NG for a *typical meteorological year (TMY)* with a 15-minute and daily resolution for various end-use subsectors such as residential and commercial space heating. The latter provides a projection of annual energy consumption for various subsectors (e.g., space heating) under different electrification scenarios between 2017 and 2050.

We first consider residential and commercial sectors and obtain their daily consumption trend from TMY profiles available from ReStock and ComStock [52]. We then scale the values of each subsectors by their corresponding annual consumption of NG in reference electrification scenario in 2050 using the data available at [51]. For high electrification scenario, we repeat the same process for all subsectors except space heating for which we scale its values based on the annual space heating consumption in 2050 under the high electrification scenario.

The monthly state level NG load for all five sectors is available in the EIA website [21].

The EIA website does not provide any information on the distribution of the monthly demand over its days. Therefore, we consider industrial and and vehicle fuel consumption in 2016 and uniformly distributed the monthly load across their corresponding days. We then scale the values based on the annual industrial and vehicle fuel consumption in 2050 under reference and high electrification scenarios. Finally, we aggregate loads for all sectors and subsectors to obtain NG consumption of each state in 2050 under the two electrification scenarios.

Once the daily NG demand is obtained for each state, we disaggregate the demand over each county based the population of counties in 2019 [66] as well as their industrialization level. We first obtain share of each county in the state's population. We then obtain the industrialization level of counties from data provided in the NREL report on county level energy use [50] which estimates the usage of industrial energy (net power, NG, coal, etc.) for each sector (manufacturing, agriculture, construction, and mining). Using this dataset, we estimate the share of industrial NG consumption of each county in the state's total industrial consumption. Subsequently, we compute demand of each county by multiplying its population share to the state's NG consumption in residential, commercial, and vehicle fuel consumption sectors, and multiplying its industrial share to state's NG consumption in industrial sector. Finally, we assign each county's load to its nearest NG node.

C.5 Emission Amounts

All England states have set a goal to reduce the emission of GHG by at least 80% until 2050 below the baselines years which is 1990 for all all states except Connecticut [68]. The total CO_2 emission for the New England states was 171.2 metric tons (mt) in 1990, of which 43.9mt was electricity energy-related emission and 23.6mt was NG energy-related emission [27]. The remaining emission was caused by consuming coal and petroleum that we do not consider in this study. Based on these figures, $U^{\text{g}}_{\text{emis}}$ = 23.6e6 and $U^{\text{e}}_{\text{emis}}$ =43.9e6.

C.6 CCS parameters

We based our estimation of CCS parameters on [63, 6, 7]. We assume that the collected carbon is stored in Appalachian Basin at a Marcellus region located in the middle of Pennsylvania [6]. We then calculate the distance between each node and the storage site. The total capacity of the Appalachian Basin is 1278 Mt (mega ton). Assuming the Basin is operable for 100 years, the total annual carbon storage capacity U^{CCS} becomes 12.78 Mt. Other parameters are calculated as follows:

- $C^{\text{inv}}_{\text{CO2}}$: Reference [7] provides CAPEX for 10 and 100 miles pipelines. We consider 100 mile pipelines as all distance values are greater than 200 miles. The CAPEX and FOM for 100 mile is 225 \$M and 1.3 \$M (million dollars), respectively. With 30 years of lifetime for CO_2 pipelines and WACC=7.1%, the CAPEX become 18.31 \$M. The FOM is given at 1.3 \$M, so the per mile investment and FOM is (18.31e6+1.3e6)/100 = 196e3 \$/mile. The reference assumes that the capacity of pipeline is 10 Mt/y (megaton per year). Therefore, the levelized investment and FOM becomes 196e3/10e6 = 0.0196 \$/mile/ton.

- $C^{\text{str}}_{\text{CO2}}$: The Appalachian basin is an aquifer type storage. The CAPEX is given at 4.3 \$M in [7] for a storage site of type aquifer with 7.3 Mt capacity per year. The CAPEX consists of injection site screening and evaluation, injection equipment, and drilling 6 wells. Assuming 30 years of lifetime, the annualized CAPEX become 350e3 \$. The FOM is given at 600e3 \$, so the levelized investment and FOM is (350e3+600e3)/7.3e6 = 0.13 \$/ton.

- E^{pipe}: For a pipeline of 100 miles long with capacity 10 Mt/year, reference [7] gives the electric requirement at 32,000 MWh/year or equivalently 32/8760e6 = 0.00365e-6 [MWh/mile/ton/hour].
- E^{pipe}: For a pipeline with capacity 10 Mt/year, each pump consume 4190 MWh electricity annually which accounts for 4190/(8760e6)=0.478e-6 MWh/ton/hour.
- E^{cprs}: Compression pump are located every 3.3 miles along the pipeline [6]. Therefore, the value is $d_n/3.3$.

We assume that CAPEX for compression pumps is negligible. Also note that these cost estimations for CCS storage are conservative as we levelized the investment and FOM costs, and do not consider other cost parameters such as labor, FOM of compression pumps and fugitive emission amount which are listed in [6].

References

[1] . Oil and gas pipeline construction costs. website, 2021. Accessed: 2022-2-1.

[2] Jamshid Aghaei, Nima Amjady, Amir Baharvandi, and Mohammad-Amin Akbari. Generation and transmission expansion planning: Milp–based probabilistic model. *IEEE Transactions on Power Systems*, 29(4):1592–1601, 2014.

[3] Northeast Gas association. Statistical guide to the northeast u.s. natural gas industry 2021. website, Nov. 2021. Accessed: 2022-3-18.

[4] Fatemeh Barati, Hossein Seifi, Mohammad Sadegh Sepasian, Abolfazl Nateghi, Miadreza Shafie-khah, and João PS Catalão. Multi-period integrated framework of generation, transmission, and natural gas grid expansion planning for large-scale systems. *IEEE Transactions on Power Systems*, 30(5):2527–2537, 2014.

[5] Luis Baringo and Ana Baringo. A stochastic adaptive robust optimization approach for the generation and transmission expansion planning. *IEEE Transactions on Power Systems*, 33(1):792–802, 2017.

[6] Madalyn S Blondes, Sean T Brennan, Matthew D Merrill, Marc L Buursink, Peter D Warwick, Steven M Cahan, Troy A Cook, Margo D Corum, William H Craddock, Christina A DeVera, et al. *National assessment of geologic carbon dioxide storage resources: methodology implementation*. US Department of the Interior, US Geological Survey, 2013.

[7] Ocean Studies Board, Engineering National Academies of Sciences, Medicine, et al. Negative emissions technologies and reliable sequestration: A research agenda. 2019.

[8] Espen Flo Bødal, Dharik Mallapragada, Audun Botterud, and Magnus Korpås. Decarbonization synergies from joint planning of electricity and hydrogen production: A texas case study. *international journal of hydrogen energy*, 45(58):32899–32915, 2020.

[9] Breakthrough Energy. U.s. test system with high spatial and temporal resolution for renewable integration studies. website, 2020. Accessed: 2022-2-8.

[10] Aron Brenner, Rahman Khorramfar, Dharik Mallapragada, and Saurabh Amin. Graph representation learning for energy demand data: Application to joint energy system planning under emissions constraints. *arXiv preprint arXiv:2209.12035*, 2022.

[11] Gregory Brinkman, Joshua Novacheck, Aaron Bloom, and James McCalley. Interconnections seam study [slides]. Technical report, National Renewable Energy Lab.(NREL), Golden, CO (United States), 2020.

[12] Maxwell Brown, Wesley Cole, Kelly Eurek, Jonathon Becker, David Bielen, Ilya Chernyakhovskiy, Stuart Cohen, Allister Frazier, Pieter Gagnon, Nathaniel Gates, et al. Regional energy deployment system (reeds) model documentation: Version 2019. Technical report, National Renewable Energy Lab.(NREL), Golden, CO (United States), 2020.

[13] Patrick R Brown and Audun Botterud. The value of inter-regional coordination and transmission in decarbonizing the us electricity system. *Joule*, 5(1):115–134, 2021.

[14] Joshua W Busby, Kyri Baker, Morgan D Bazilian, Alex Q Gilbert, Emily Grubert, Varun Rai, Joshua D Rhodes, Sarang Shidore, Caitlin A Smith, and Michael E Webber. Cascading risks: Understanding the 2021 winter blackout in texas. *Energy Research & Social Science*, 77:102106, 2021.

[15] Modassar Chaudry, Nick Jenkins, Meysam Qadrdan, and Jianzhong Wu. Combined gas and electricity network expansion planning. *Applied Energy*, 113:1171–1187, 2014.

[16] Changgwon Choe, Boreum Lee, Ayeon Kim, Seunghyun Cheon, and Hankwon Lim. Comprehensive assessment of CO_2 methanation: which H_2 production pathway is practicable for green methane production in terms of technical, economic, and environmental aspects? *Green Chemistry*, 23(23):9502–9514, 2021.

[17] Wesley Cole, A Will Frazier, and Chad Augustine. Cost projections for utility-scale battery storage: 2021 update. Technical report, National Renewable Energy Lab.(NREL), Golden, CO (United States), 2021.

[18] Wesley J Cole, Danny Greer, Paul Denholm, A Will Frazier, Scott Machen, Trieu Mai, Nina Vincent, and Samuel F Baldwin. Quantifying the challenge of reaching a 100% renewable energy power system for the united states. *Joule*, 5(7):1732–1748, 2021.

[19] Athanasios S Dagoumas and Nikolaos E Koltsaklis. Review of models for integrating renewable energy in the generation expansion planning. *Applied Energy*, 242:1573–1587, 2019.

[20] Tao Ding, Yuan Hu, and Zhaohong Bie. Multi-stage stochastic programming with nonanticipativity constraints for expansion of combined power and natural gas systems. *IEEE Transactions on Power Systems*, 33(1):317–328, 2017.

[21] Energy Information Administration (EIA). Eia website. Website, Mar. 22 2022. Accessed: 2022-2-18.

[22] Energy Information Administration (EIA). Eia website. Website, Mar. 22 2022. Accessed: 2022-12-14.

[23] Dominion Energy. Green river satellite lng facility basis of cost estimation. website, Mar. 2019. Accessed: 2022-3-18.

[24] Energy Information Administration (EIA). Emission coefficients. website, 2021. Accessed: 2022-2-8.

[25] Energy Information Administration (EIA). U.s. energy facts explained. website, 2021. Accessed: 2022-2-8.

[26] Energy Information Administration (EIA). U.s. energy facts explained. website, 2021. Accessed: 2022-10-8.

[27] Energy Information Administration (EIA). Energy-related co2 emission data tables. website, 2022. Accessed: 2022-2-8.

[28] ISO New England. Final 2022 heating electrification forecast. 2022.

[29] Meisam Farrokhifar, Yinghui Nie, and David Pozo. Energy systems planning: A survey on models for integrated power and natural gas networks coordination. *Applied Energy*, 262:114567, 2020.

[30] Martin Gassner and François Maréchal. Thermo-economic optimisation of the polygeneration of synthetic natural gas (sng), power and heat from lignocellulosic biomass by gasification and methanation. *Energy & Environmental Science*, 5(2):5768–5789, 2012.

[31] Omar J Guerra, Diego A Tejada, and Gintaras V Reklaitis. An optimization framework for the integrated planning of generation and transmission expansion in interconnected power systems. *Applied energy*, 170:1–21, 2016.

[32] Maryam Hamedi, Reza Zanjirani Farahani, Mohammad Moattar Husseini, and Gholam Reza Esmaeilian. A distribution planning model for natural gas supply chain: A case study. *Energy Policy*, 37(3):799–812, 2009.

[33] Jeremy J Hargreaves and Ryan A Jones. Long term energy storage in highly renewable systems. *Frontiers in Energy Research*, 8:219, 2020.

[34] E3 Inc. and EFI. Net-zero new england: Ensuring electric reliability in a low-carbon future. 2020.

[35] MIT Energy Initiative. The future of energy storage, 2022.

[36] Gopika Jayadev, Benjamin D Leibowicz, and Erhan Kutanoglu. Us electricity infrastructure of the future: Generation and transmission pathways through 2050. *Applied energy*, 260:114267, 2020.

[37] Jesse D Jenkins and Nestor A Sepulveda. Enhanced decision support for a changing electricity landscape: the genx configurable electricity resource capacity expansion model. 2017.

[38] Emmanuel Kasseris, Naga Srujana Goteti, Sapna Kumari, Bentley Clinton, Seiji Engelkemier, Sarah Torkamani, Tevita Akau, and Emre Gençer. Highlighting and overcoming data barriers: creating open data for retrospective analysis of us electric power systems by consolidating publicly available sources. *Environmental Research Communications*, 2(11):115001, 2020.

[39] Nikolaos E Koltsaklis and Athanasios S Dagoumas. State-of-the-art generation expansion planning: A review. *Applied energy*, 230:563–589, 2018.

[40] Leander Kotzur, Peter Markewitz, Martin Robinius, and Detlef Stolten. Time series aggregation for energy system design: Modeling seasonal storage. *Applied Energy*, 213:123–135, 2018.

[41] Uisung Lee, Arpit Bhatt, Troy Robert Hawkins, Ling Tao, Pahola Thathiana Benavides, and Michael Wang. Life cycle analysis of renewable natural gas and lactic acid production from waste feedstocks. *Journal of Cleaner Production*, 311:127653, 2021.

[42] Can Li, Antonio J Conejo, Peng Liu, Benjamin P Omell, John D Siirola, and Ignacio E Grossmann. Mixed-integer linear programming models and algorithms for generation and transmission expansion planning of power systems. *European Journal of Operational Research*, 297(3):1071–1082, 2022.

[43] Dharik S Mallapragada, Gang Duan, and Rakesh Agrawal. From shale gas to renewable energy based transportation solutions. *Energy Policy*, 67:499–507, 2014.

[44] Dharik S Mallapragada, Eric Reyes-Bastida, Frank Roberto, Erin M McElroy, Dejan Veskovic, and Ian J Laurenzi. Life cycle greenhouse gas emissions and freshwater consumption of liquefied marcellus shale gas used for international power generation. *Journal of Cleaner Production*, 205:672–680, 2018.

[45] P Duenas Martinez. Analysis of the operation and contract management in downstream natural gas markets. *Pontificial University Comillas (ICAI)(Institute for Research in Technology)*, 2013.

[46] J Mesko and J Ramsey. The use of liquefied natural gas for peaking service. 66. 1996.

[47] Caitlin Murphy, Trieu Mai, Yinong Sun, Paige Jadun, Matteo Muratori, Brent Nelson, and Ryan Jones. Electrification futures study: Scenarios of power system evolution and infrastructure development for the united states. Technical report, National Renewable Energy Lab.(NREL), Golden, CO (United States); Northern ..., 2021.

[48] NREL. 2021 annual technology baseline (atb). website, 2021. Accessed: 2022-2-8.

[49] NREL. Electrification futures study load profiles. website, Aug. 2022. Accessed: 2022-8-21.

[50] NREL Report on IED. 2018 industrial energy data book. website, 2018. Accessed: 2021-12-25.

[51] U.S. Department of Energy Office of Scientific and Technical Information. Electrification futures study scenarios of electric technology adoption and power consumption for the united states. Website, Aug. 22 2022. Accessed: 2022-8-18.

[52] U.S. Department of Energy Office of Scientific and Technical Information. End-use load profiles for the u.s. building stock. Website, June 22 2022. Accessed: 2022-6-18.

[53] Bryan S Palmintier and Mort D Webster. Impact of operational flexibility on electricity generation planning with renewable and carbon targets. *IEEE Transactions on Sustainable Energy*, 7(2):672–684, 2015.

[54] David Pozo, Enzo E Sauma, and Javier Contreras. A three-level static milp model for generation and transmission expansion planning. *IEEE Transactions on Power systems*, 28(1):202–210, 2012.

[55] Jing Qiu, Hongming Yang, Zhao Yang Dong, Jun Hua Zhao, Ke Meng, Feng Ji Luo, and Kit Po Wong. A linear programming approach to expansion co-planning in gas and electricity markets. *IEEE Transactions on Power Systems*, 31(5):3594–3606, 2015.

[56] Daniel Raimi. Decommissioning us power plants. *Decisions, costs, and key issues. Resources for the Future (RFF) Report*, 2017.

[57] Albert Reuther, Jeremy Kepner, Chansup Byun, Siddharth Samsi, William Arcand, David Bestor, Bill Bergeron, Vijay Gadepally, Michael Houle, Matthew Hubbell, et al. Interactive supercomputing on 40,000 cores for machine learning and data analysis. In *2018 IEEE High Performance extreme Computing Conference (HPEC)*, pages 1–6. IEEE, 2018.

[58] Isam Saedi, Sleiman Mhanna, and Pierluigi Mancarella. Integrated electricity and gas system modelling with hydrogen injections and gas composition tracking. *Applied Energy*, 303:117598, 2021.

[59] Carlos Saldarriaga-Cortés, Harold Salazar, Rodrigo Moreno, and Guillermo Jiménez-Estévez. Stochastic planning of electricity and gas networks: An asynchronous column generation approach. *Applied energy*, 233:1065–1077, 2019.

[60] Nestor A Sepulveda, Jesse D Jenkins, Aurora Edington, Dharik S Mallapragada, and Richard K Lester. The design space for long-duration energy storage in decarbonized power systems. *Nature Energy*, 6(5):506–516, 2021.

[61] Chengcheng Shao, Mohammad Shahidehpour, Xifan Wang, Xiuli Wang, and Biyang Wang. Integrated planning of electricity and natural gas transportation systems for enhancing the power grid resilience. *IEEE Transactions on Power Systems*, 32(6):4418–4429, 2017.

[62] Holger Teichgraeber and Adam R Brandt. Time-series aggregation for the optimization of energy systems: Goals, challenges, approaches, and opportunities. *Renewable and Sustainable Energy Reviews*, 157:111984, 2022.

[63] Gary Teletzke, Jeffrey Palmer, Eric Drueppel, Michael B Sullivan, Kenneth Hood, Ganeswara Dasari, and Gregory Shipman. Evaluation of practicable subsurface co2 storage capacity and potential co2 transportation networks, onshore north america. In *14th Greenhouse Gas Control Technologies Conference Melbourne*, pages 21–26, 2018.

[64] United States Nuclear Regulatory Commission. Backgrounder on decommissioning nuclear power plants. website, 2021. Accessed: 2022-2-8.

[65] Clodomiro Unsihuay-Vila, Jose Wanderley Marangon-Lima, AC Zambroni De Souza, Ignacio J Perez-Arriaga, and Pedro P Balestrassi. A model to long-term, multiarea, multistage, and integrated expansion planning of electricity and natural gas systems. *IEEE Transactions on Power Systems*, 25(2):1154–1168, 2010.

[66] US Census 2019. County population totals: 2010-2019. website, 2021. Accessed: 2021-12-16.

[67] Gregory Von Wald, Kaarthik Sundar, Evan Sherwin, Anatoly Zlotnik, and Adam Brandt. Optimal gas-electric energy system decarbonization planning. *Advances in Applied Energy*, page 100086, 2022.

[68] Jurgen Weiss and J. Michael Hagerty. Achieving 80% ghg reduction in new england by 2050. 2019.

[69] Yixing Xu, Nathan Myhrvold, Dhileep Sivam, Kaspar Mueller, Daniel J Olsen, Bainan Xia, Daniel Livengood, Victoria Hunt, Benjamin Rouillé d'Orfeuil, Daniel Muldrew, et al. Us test system with high spatial and temporal resolution for renewable integration studies. In *2020 IEEE Power & Energy Society General Meeting (PESGM)*, pages 1–5. IEEE, 2020.

[70] Ning Zhang, Zhaoguang Hu, Cecilia Springer, Yanning Li, and Bo Shen. A bi-level integrated generation-transmission planning model incorporating the impacts of demand response by operation simulation. *Energy Conversion and Management*, 123:84–94, 2016.

[71] Yao Zhang, Yuan Hu, Jin Ma, and Zhaohong Bie. A mixed-integer linear programming approach to security-constrained co-optimization expansion planning of natural gas and electricity transmission systems. *IEEE Transactions on Power Systems*, 33(6):6368–6378, 2018.

[72] Bining Zhao, Antonio J Conejo, and Ramteen Sioshansi. Coordinated expansion planning of natural gas and electric power systems. *IEEE Transactions on Power Systems*, 33(3):3064–3075, 2017.

Table 1: Summary of data inputs and sources

Data	Description	Notes
Annual discount rate	7.1%	applied to all investments in the model uniformly
	Power System	
Power sector resource capital costs	Sourced for year 2050 – see Table 4	Based on NREL Annual technology baseline [48]
Electric transmission line investment costs	3500 $/MW/mile	Based on Regional Energy Deployment System (ReEDS) [12]
Electric network topology data	Explained in C.2	Sourced mainly from [9], [48], [60], [12]
Electricity demand scenarios	Explained in C.4	Based on NREL's Electrification Future Study Load Profile dataset [49]
	NG System	
Gas system demand scenarios	Explained in C.4	Based on [49] and [21]
Gas network topology data	Explained in C.3	Based on [21]
Gas SVL nodes	Explained in C.3	Sourced mainly from [3]
Gas pipeline investment costs	5.34 million $/mile	Based on [1]
NG import price	5.45 $/MMBtu	Represents cost of fossil NG injections into different nodes in the network. Based on [60]
LCDF import price	20 $/MMBtu	Represents cost of LCDF injection into the network. Based on [18]
CO_2 emissions constraints	Explained in C.5	Based on [27]
Case C1: power sector only emissions limits	35, 37, 39, 41 million tons for 80% to 95% decarbonization goals, respectively	
Case C2 and C3 (combined NG and power sector emissions limits)	54, 57, 61, 64 million tons for 80% to 95% decarbonization goal, respectively	
Emission factor	0.053 ton/MMBtu for NG, 0 for LCDF	from [21]

Table 2: Summary of major data input, their values, and references

	ng	solar	wind	hydro	nuclear
CT	4375	12	5		1888
MA	1763	3	40	0	0
ME	0	0	629	529	0
NH	1808	0	78	349	1226
RI	6667	369	65	1432	617
VT	0	61	111	199	0

Table 3: Capacity of existing plants at each state (MW)

Table 4: Parameter Values for Existing Plants

Symbol	Parameter\Type	ng	solar	wind	hydro	nuclear
	FOM [$/kW/year][1]	21	23	43	78	145
C_i^{var}	VOM [$/MWh][2]	5	0	0	0	2
η_i	CO_2 Capture [%][3]	0	-	-	-	-
h_i	Heat Rate [MMBtu/MWh][4]	8.7	0	0	0	10.6
$\tilde{C}_i^{\text{dec}}$	Decom. cost per plant [$][5]	5.0e6	4.5e4	1e6	-	3.0e8
U_i^{prod}	Nameplate capacity [MW][6]	173	6.3	42	23	933
L_i^{prod}	Min stable output [%][7]	31	0	0	0	42
U_i^{ramp}	Hourly Ramp rate [%][8]	96	-	-	-	25
C_i^{fix}	FOM per plant [$/MW/year][9]	3.6e6	1.45e5	1.8e6	1.8e6	1.4e8
C_i^{startUp}	Startup Cost [$][11]	4.52e4	-	-	-	4.6e4

[1] and [2] from [48] in year 2019, [3] from [24], [4] approximated from linear and quadratic coefficient of heat rate curve provided in [9], [5] estimated from [56] except for nuclear which is obtained from [64]. Decommissioning of hydro plants is not considered, [6] and [7] from [9], [8] estimated from 30-min ramp rate in [9], [9] $r1 * 1000 * r6$ where $r1$ is the FOM value in $r1$ and $r6$ is nameplate capacity provide in row6, [11] from [60]. Startup cost for "ng" type is assumed to be the same as "CCGT" type.

Table 5: Parameter Values for New Plants

Symbol	Parameter\Type	OCGT	CCGT	CCGT-CCS	solar-UPV	windN	wind-o
	CAPEX [$/kW][1]	780	935	2167	672	808	
	FOM [$/kW/year][2]	21	27	65	15	35	
C_i^{var}	VOM [$/MWh][3]	5	2	6	0	0	
η_i	CO_2 Capture [%][4]	0	0	90	-	-	
h_i	Heat Rate [MMBtu/MWh][5]	9.72	6.36	7.16	0	0	
	Lifetime [year]	30	30	30	30	30	
U_i^{prod}	Nameplate capacity [MW][6]	237	573	400	10	10	
$\tilde{C}_i^{\text{inv}}$	CAPEX per Plant [$][7]	1.85e8	5.36e8	8.67e8	6.72e6	8.01e6	
L_i^{prod}	Minimum stable output [%][8]	25	33	50	0	0	
U_i^{ramp}	Hourly ramping rate [%][9]	100	100	100	-	-	
C_i^{fix}	FOM per plant [$/yr][10]	5.0e6	1.55e7	2.6e7	1.5e5	3.5e5	
C_i^{startUp}	Startup Cost [$][11]	8.0e3	4.52e4	3.79e4	-	-	

[1−5] from [48] in year 2045. For CCGT-CCS, "Conservative" technology class is considered. For "windN" and wind-offshore "Moderate-Class4" technology class is considered. For all others "Moderate" cost assumption is considered, [6] from [60] for "OCGT", "CCGT", CCGT-CCS, and "nuclearN". For VRE, a modular capacity of 10MW is considered, [7] $r1 * 1000 * r6$ where $r1$ is the CAPEX value in row[1] and $r6$ is nameplate capacity provide in row[6], [8] from [60], [9] from [60], [10] $r2 * 1000 * r6$ where $r2$ is the FOM value in $r1$ and $r6$ is nameplate value provide in $r7$, [11] from [60]

Table 6: power storage parameters

Symbol	Parameter	Li-ion	Metal-air (low)[1]	Metal-air (high)[2]
$\tilde{C}^{\text{EnInv}}$	Energy capital cost [$/kW]	129[3]	0.1	3.6
$\tilde{C}^{\text{pInv}}$	Energy power cost [$ /kWh]	156[4]	595	950
γ_r^{eCh}	Charge efficiency	0.92[5]	0.7	0.72
γ_r^{eDis}	Discharge efficiency	0.92[6]	0.59	0.6
C_r^{EnInv}	Energy related FOM ($/kWh/year)	3.22[7]	0	100
C_r^{pInv}	Power related FOM ($/kW/year)	3.9[8]	14.9	23.7
γ_r^{selfD}	hourly self-discharge rate	2.08e-5[9]	2.08e-5	2.08e-5
	Lifetime	15[10]	25	25

columns [1] and [2] from [35],
[3] and [4] from [48] in year 2045 averaged over "Advance", "Moderate" and "Conservative" estimates, [5] and [6] from [48] where the round-trip efficiency is provided at 85%, [7] and [8] 2.5% of energy capital and power cost (row 1 and 2), respectively [17], [9] from [35] the monthly self-discharge provided at 1.5%, [8] from [48]

Table 7: Other parameters for power network

Symbol	Parameter	Value
	Transmission line lifetime [year]	30
	Weighted average cost of capital (WACC)[1]	7.1%
$\tilde{C}_{\ell}^{\text{trans}}$	Transmission line investment cost [$/MW/mile][2]	3500
	Li-ion Battery lifetime [year][3]	30
	Transmission line lifetime [year][4]	30
	Uranium price [$/MMBtu][5]	0.72

[1] from [60], [2] from [12], [3] from [48], [4] from [48] in year 2045, [5] from [60] in year 2045

Table 8: Resource Availability Data

$\mathcal{Q}$	Maximum Available Value
"solar", solar-UPV	22 GW
"wind", "windN"	10 GW
wind-offshore	280 GW
"nuclear", "nuclearN"	3.5 GW

Resource availability amounts are obtained from [34]

Table 9: Regional CAPEX multipliers for new plant types

State/Technology	OCGT	CCGT	CCGT-CCS	solar-UPV	wind	wind-offshore	nuclear
Connecticut (CT)	1.25	1.3	1.3	1.15	1.4	1.1	1.1
Massachusetts (MA)	1.1	1.1	1.1	1.05	1.35	1.1	1.05
Maine (ME)	1.25	1.3	1.3	1.1	1.35	1.1	1.1
New Hampshire (NH)	1.1	1.1	1.1	1.05	1.35	1.1	1.05
Rhode Island (RI)	1.2	1.25	1.25	1.1	1.35	1.1	1.05
Vermont (VT)	1.1	1.1	1.1	1.05	1.35	1.1	1.05

Table 10: Other parameters for NG/SVL network

Parameter	Value	
$\tilde{C}_j^{\text{strInv}}$	Storage tank CAPEX[1] [$/MMBtu]	729.1
$\tilde{C}_j^{\text{vprInv}}$	Vaporization CAPEX[2] [$/MMBtu]	1818.31
C_j^{strFix}	Storage tank FOM[3] [$/MMBtu]	3.6
C_j^{vprFix}	Vaporization FOM[4] [$/MMBtu/d]	327.3
γ_j^{ligCh}	Liquefaction charge efficiency (%)	100
γ_j^{vprDis}	Vaporization discharge efficiency[5] (%)	98.9
	Pipeline lifetime [year]	30
C_j^{gShed}	NG load shedding cost [$/MMBtu]	1000
η^{g}	Emission factor for NG [6] [ton/MMBtu]	0.053
C^{alt}	LCDF price [$/MMBtu][7]	20
	SVL lifetime [year]	30
$\tilde{C}_\ell^{\text{pipe}}$	Pipeline investment cost [$/mile][8]	5.34e6
C^{ng}	NG price [$/MMBtu][9]	5.45

[1] from Table 1 of [23], [2] from Table 1 of [23], [3] 0.5% of CAPEX according to [46], [4] 1.8% of CAPEX according to [46], [5] estimated from [44], [6] from [21], [7] from [18], [8] approximated from [1], [9] from [60]

Table 11: Actual emission budget (ton)

	$\zeta = 80\%$	$\zeta = 85\%$	$\zeta = 90\%$	$\zeta = 95\%$
C1	3.51e7	3.73e7	3.95e7	4.17e7
C2 and C3	5.4e7	5.74e7	6.08e7	6.41e7